

C3 FIELD DEVICE RECORD

(Reference: Clause 6.1 6)

C6.1 FIELD DEVICE TESTING - LEGEND & NOTES

(Reference: Clauses 6.7.4.1.3, 6.7.4.1.4, 6.7.4.1.5, 6.7.4.3.1, 6.7.4.5.1, 6.7.8.1.1, 6.7.8.2.2, 6.7.8.2.4)

DEVICE	DESCRIPTION	MANUFACTURER	MODEL NO.
M	Manual Station	EDWARDS	270-SPOWB
M2	Manual Station		
M3	Manual Station		
RHT	Rate of Rise Heat Detector		281C
RHT2	Rate of Rise Heat Detector	SYSTEM SENSOR	5601A
RHT3	Rate of Rise Heat Detector		
HT	Fixed Temperature Heat Detector		
HT2	Fixed Temperature Heat Detector		
HT3	Fixed Temperature Heat Detector		
S	Smoke Detector	EST	EDW2151A
	Sensitivity Test Method:		
	Sensitivity Range:		
S2	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
S3	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
RI	Remote Indicator		
DS	Duct Smoke Detector		
SFD	Supporting Field Device - Monitor		
SFD2	Supporting Field Device - Monitor		
FD	Sprinkler Flow Switch		
SS	Sprinkler Supervisory Device		
PS	Sprinkler Pressure Device		
IM	Isolation Module		
B	Bell	EDWARDS	MB10-24
B2	Bell		
H/V	Horn/Visual		
H/V2	Horn/Visual		
H	Horn		
H2	Horn		
V	Visual Signal Device	EST	202-7A-T
V2	Visual Signal Device		
SP	Cone Type Speaker		
SP2	Cone Type Speaker		
HSP	Horn Type Speaker		
AD	Ancillary Device		
AD2	Ancillary Device		
ET	Emergency Telephone		
EOL	End of Line Resistor/Capacitor		
EOL2	End of Line Resistor/Capacitor		

BUILDING NAME:	RCMP WINNIPEGOSIS DETACHMENT
BUILDING ADDRESS:	434 1ST ST. WINNIPEGOSIS MB.
DATE:	Wednesday, January 5, 2022

C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
FRONT ENTRANCE RECEPTION AREA	FACP	EST1	✓		✓	✓	✓		
SIGNALS :									
GENERAL OFFICE BY FRONT DESK	B	NAC1	✓		✓	✓			
BASEMENT BOILER/ FURNACE ROOM	B	NAC1	✓		✓	✓			
GARAGE	B	NAC1	✓		✓	✓			
CELL AREA	B	NAC1	✓		✓	✓			
BASEMENT WEIGHT ROOM	B	NAC1	✓		✓	✓			
GENERAL OFFICE S/W									
GENERAL OFFICE S/W	V	NAC1	✓		✓	✓			
BASEMENT MENS WASHROOM	V	NAC1	✓		✓	✓			
PUBLIC WASHROOM	V	NAC1	✓		✓	✓			
DEVICES :									
BASEMENT:									
ENTRANCE BY PULL	RHT	Z1	✓		✓		✓		
FURNACE ROOM	RHT	Z1	✓		✓		✓		
FILE/STORAGE ROOM	S	Z1	✓		✓		✓		jan 2022 changed to a smoke
ENTRANCE	M	Z1	✓		✓		✓		
WOMENS LOCKER ROOM	RHT	Z1	✓		✓		✓		
WOMENS WASHROOM	RHT	Z1	✓		✓		✓		
WEIGHT ROOM FORNT OF MIRROR	RHT2	Z1	✓		✓		✓		
WEST BASEMENT BY MENS LOCKER ROOM	RHT	Z1	✓		✓		✓		
MENS LOCKER ROOM SOUTH	RHT	Z1	✓		✓		✓		
MENS LOCKER ROOM NORTH	RHT	Z1	✓		✓		✓		
MENS WASHROOM	RHT	Z1	✓		✓		✓		
BY STAIRS	EOL	Z1	✓		✓				
CELL AREA :									
BY ENTRANCE TO ADMIN. AREA	EOL	Z2	✓		✓				
ENTRANCE	M	Z2	✓		✓		✓		
GUARDS AREA	S	Z2	✓		✓		✓		
CELL HALL BY CELL 2	S	Z2	✓		✓		✓		
EXIT TO GARAGE	M	Z2	✓		✓		✓		
INTERVIEW ROOM	S	Z2	✓		✓		✓		REPLACED 2022
IDENTIFICATION / BREATHALYZER ROOM	S	Z2	✓		✓		✓		REPLACED 2022
WASHROOM	S	Z2	✓		✓		✓		jan 2022 changed to a smoke
PIPE CHASE 1	S	Z2	✓		✓		✓		INSTALLED 2022
PIPE CHASE 2	S	Z2	✓		✓		✓		INSTALLED 2022
ADMIN. AREA :									

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
FRONT MAIN ENTRANCE	M	Z3	✓		✓		✓		
KITCHEN	S	Z3	✓		✓		✓		
GENERAL OFFICE EAST	S	Z3	✓		✓		✓		
INTERVIEW ROOM	RHT	Z3	✓		✓		✓		
MEMBERS BACK EXIT	M	Z3	✓		✓		✓		
MEMBERS BACK EXIT	S	Z3	✓		✓		✓		
GENERAL OFFICE WEST	S	Z3	✓		✓		✓		
COPY FILE ROOM	S	Z3	✓		✓		✓		Jan 2022 changed to a smoke
CORPORALS OFFICE BY FILE ROOM	RHT2	Z3	✓		✓		✓		REPLACED JAN 2022
TEMPORARY EXHIBIT ROOM	S	Z3	✓		✓		✓		
MAIN EXHIBIT ROOM	S	Z3	✓		✓		✓		
JANITORS ROOM	RHT	Z3	✓		✓		✓		
PUBLIC WASHROOM	RHT	Z3	✓		✓		✓		
REAR EXIT	EOL	Z3	✓		✓				
SARGENTS OFFICE	RHT	Z3	✓		✓		✓		
SECURE BAY:									
GARAGE EAST EXIT	M	Z4	✓		✓		✓		
CENTRE GARAGE	RHT	Z4	✓		✓		✓		
GARAGE EAST EXIT	EOL	Z4	✓		✓				
CELL 1:									
CELL 1	S	Z5	✓		✓		✓		
CELL CORRIDOR	EOL	Z5	✓		✓				
CELL 2:									
CELL 2:	S	Z6	✓		✓		✓		
CELL CORRIDOR	EOL	Z6	✓		✓				
CELL 3:									
CELL 3	S	Z7	✓		✓	✓	✓		
CELL CORRIDOR	EOL	Z7	✓		✓	✓			
WEST STAIR :									
WEST STAIRWELL	S	Z8	✓		✓		✓		
WEST STAIRS	EOL	Z8	✓		✓				

BUILDING NAME:	RCMP WINNIPEGOSIS DETACHMENT		
BUILDING ADDRESS:	434 1ST ST. WINNIPEGOSIS MB.		
DATE:	Wednesday, January 5, 2022		
TEST NG PERFORMED BY:			

Printed Name

Signature

EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service damaged, poor, or light battery condition	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, x = Fail	Remarks / Deficiencies / Corrective Action
#1 MAIN FLOOR JANITORS ROOM	BP	24V		550W		✓			30	✓	EMERGH-LITE 24ESL550. 2-12V 35AH BATTER ES.
CELL AREA HALL	RH2					✓	✓			✓	
GUARDS DESK	RH2					✓	✓			✓	
GUARDS AREA EXIT	ES					✓		✓		✓	
GUARDS AREA ENTRANCE	ES					✓		✓		✓	
TOP OF BASEMENT STAIRS	RH2					✓	✓			✓	
MEMBERS BACK HALL EXIT	ES					✓		✓		✓	
MEMBERS BACK HALL	RH2					✓	✓			✓	
OFFICE WASHROOM	RH1					✓	✓			✓	
GENERAL OFFICE NORTH	RH2					✓	✓			✓	
GENERAL OFFICE S/E	RH2					✓	✓			✓	
GENERAL OFFICE HALL WEST	ES					✓		✓		✓	
GENERAL OFFICE ENTRANCE TO WEST	ES					✓		✓		✓	
MAIN ENTRANCE	ES					✓		✓		✓	
LOBBY WASHROOM	RH1					✓	✓			✓	
RECEPTION AREA	RH2					✓	✓			✓	
GARAGE EAST EXIT	ES					✓		✓		✓	
GARAGE SOUTH WALL	RH2					✓	✓			✓	
BASEMENT S/W WALL	2BP	24V		550W		✓	✓		30	✓	
FURNACE ROOM	RH2				x	✓	✓			✓	REQUIRES 24V 18W BULB REPLACEMENT
BASEMENT WOMENS WASHROOM	RH2					✓	✓			✓	
BASEMENT WOMENS LOCKER ROOM	RH2					✓	✓			✓	
BASEMENT ENTRANCE	RH2					✓	✓			✓	
BASEMENT ENTRANCE	ES					✓		✓		✓	
BASEMENT WEIGHT ROOM	RH1					✓	✓			✓	
BASEMENT MENS LOCKER ROOM	RH1					✓	✓			✓	
BASEMENT MENS WASHROOM	RH2					✓	✓			✓	
BASEMENT FILE/STORAGE ROOM	RH2					✓	✓			✓	