

BUILDING NAME:	RCMP WABOWDEN DETACHMENT
BUILDING ADDRESS:	364 FLEMING DRIVE WABOWDEN MB.
DATE:	TUESDAY MARCH 29,2022

C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
ELECTRICAL ROOM	FACP	MIRCOM SERIES 200	✓		✓	✓	✓		O6
FRONT ENTRANCE VESTIBULE	ANN	MIRCOM	✓		✓	✓	✓		
DEVICES:									
ZONE 1:									
HALL BY GARAGE1 CELL AREA	S	Z1	✓		✓	✓	✓	2.4%	
HALL BY BACK STORAGE	S	Z1	✓		✓	✓	✓	2.4%	
GARAGE 1	HT	Z1	✓		✓	✓	✓		O1
JANITORS ROOM BY GARAGE 2	HT	Z1	✓		✓	✓	✓		O1
GARAGE 2	M	Z1	✓		✓	✓	✓		
GARAGE 2	HT	Z1	✓		✓	✓	✓		O1
GARAGE 2	EOL	Z1	✓		✓	✓			
BREATHALIZER ROOM	S	Z1	✓		✓	✓	✓	2.4%	
CELL AREA WASHROOM	S	Z1	✓		✓	✓	✓	2.4%	
CELL 1	S	Z1	✓		✓	✓	✓	2.4%	O2
CELL 2 STORAGE	S	Z1	✓		✓	✓	✓	2.6%	
CELL 3	S	Z1	✓		✓	✓	✓	2.4%	
PRINT/PHOTO ROOM	S	Z1	✓		✓	✓	✓	2.4%	
STORAGE ROOM	S	Z1	✓		✓	✓	✓	2.4%	
CELL AREA PIPESHASE ROOM	HT	Z1	✓		✓	✓	✓		O1
ZONE 2:									
ELECTRICAL ROOM	S	Z2	✓		✓	✓	✓	2.4%	
LUNCH ROOM	HT	Z2	✓		✓	✓	✓		O1
EXHIBIT ROOM 1	S	Z2	✓		✓	✓	✓	2.6%	
MAIN EXHIBIT ROOM	S	Z2	✓		✓	✓	✓	2.6%	
GYM	HT	Z2	✓		✓	✓	✓		O1
STAFF EXIT	M2	Z2	✓		✓	✓	✓		
FRONT ENTRANCE	M	Z2	✓		✓	✓	✓		O3
MECHANICAL ROOM FRONT	HT	Z2	✓		✓	✓	✓		O1
MECHANICAL ROOM BACK	HT2	Z2	✓		✓	✓	✓		O1
GENERAL OFFICE	S	Z2	✓		✓	✓	✓	2.4%	
INTERVIEW ROOM	S	Z2	✓		✓	✓	✓	2.4%	
FILE ROOM	S	Z2	✓		✓	✓	✓	2.6%	
SIGNALS:									
BY LUNCH ROOM	B	NAC2	✓		✓				
GENERAL OFFICE AREA	B	NAC2	✓		✓				
BACK AREA	B	NAC2	✓		✓				
GARAGE 2	B	NAC2	✓		✓				
FAN SHUT DOWN	AD		✓		✓	✓			

BUILDING NAME:	RCMP WABOWDEN DETACHMENT	
BUILDING ADDRESS:	364 FLEMING DRIVE WABOWDEN MB.	
DATE:	TUESDAY MARCH 29,2022	
TEST NG PERFORMED BY:		

Printed Name

Signature

EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service (damaged, poor light, battery condition)	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, ✗ = Fail	Remarks / Deficiencies / Corrective Action
EXHIBIT ROOM	2BP	12V		160W	x	✓	✓			x	DUAL LITE C12AS-160-BCI 3-12V 12AH BATTERIES. D1.
GENERAL OFFICE	2BP	12V		56W		✓	✓		30	✓	LUMACELL RG125362LD7. 2-6V 5AH BATTERIES.
MECHANICAL ROOM	2BP	12V		144W		✓	✓		30	✓	LUMACELL RG12S144MT9W. 2-6V 12AH BATTER ES.
CELL AREA	2BP	6V		72W		✓	✓		30	✓	LUMACELL RGC272MT9W. 1-6V 5AH BATTERY. O4
GARAGE 1	2BP	6V		72W		✓	✓		30	✓	LUMACELL RGC272MT9W. 1-6V 5AH BATTERY.
GARAGE 2	2BP	6V		72W		✓	✓		30	✓	LUMACELL RGC272MT9W. 1-6V 7AH BATTERY. O5