

C3 FIELD DEVICE RECORD

(Reference: Clause 6.1 6)

C6.1 FIELD DEVICE TESTING - LEGEND & NOTES

(Reference: Clauses 6.7.4.1.3, 6.7.4.1.4, 6.7.4.1.5, 6.7.4.3.1, 6.7.4.5.1, 6.7.8.1.1, 6.7.8.2.2, 6.7.8.2.4)

DEVICE	DESCRIPTION	MANUFACTURER	MODEL NO.
M	Manual Station	EDWARDS	270-SPOW
M2	Manual Station		
M3	Manual Station		
RHT	Rate of Rise Heat Detector	SYSTEM SENSOR	5601A
RHT2	Rate of Rise Heat Detector		
RHT3	Rate of Rise Heat Detector		
HT	Fixed Temperature Heat Detector	EST	284B-PL
HT2	Fixed Temperature Heat Detector		
HT3	Fixed Temperature Heat Detector		
S	Smoke Detector	EDWARDS	EDW2151A
	Sensitivity Test Method:		
	Sensitivity Range:		
S2	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
S3	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
RI	Remote Indicator		
DS	Duct Smoke Detector		
SFD	Supporting Field Device - Monitor		
SFD2	Supporting Field Device - Monitor		
FD	Sprinkler Flow Switch		
SS	Sprinkler Supervisory Device		
PS	Sprinkler Pressure Device		
IM	Isolation Module		
B	Bell		
B2	Bell		
H/V	Horn/Visual	EST	
H/V2	Horn/Visual		
H	Horn		
H2	Horn		
V	Visual Signal Device		
V2	Visual Signal Device		
SP	Cone Type Speaker		
SP2	Cone Type Speaker		
HSP	Horn Type Speaker		
AD	Ancillary Device		
AD2	Ancillary Device		
ET	Emergency Telephone		
EOL	End of Line Resistor/Capacitor		EOL-P1
EOL2	End of Line Resistor/Capacitor		

BUILDING NAME:	RCMP BRANDON DETACHMENT
BUILDING ADDRESS:	SITE 500 BOX 12 RR5 VETERANS WAY BRANDON MB.
DATE:	WEDNESDAY FEB. 2,2022

C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
GENERAL OFFICE ENTRANCE	FACP	EST FS305	✓		✓	✓	✓		
DEVICES :									
MAIN FLOOR ZONE 1:									
BY FACP	M	Z1	✓		✓	✓	✓		
HANDI-CAP WASHROOM	RHT	Z1	✓		✓	✓	✓		
GENERAL OFFICE	S	Z1	✓		✓	✓	✓		
PUBLIC WASHROOM	RHT	Z1	✓		✓	✓	✓		
FIRE ARMS OFFICE	S	Z1	✓		✓	✓	✓		
IT ROOM	S	Z1	✓		✓	✓	✓		
BY BASEMENT STAIRS	S	Z1	✓		✓	✓	✓		
BY REAR EXIT	M	Z1	✓		✓	✓	✓		
BOARDROOM	S	Z1	✓		✓	✓	✓		
BOARDROOM	M	Z1	✓		✓	✓	✓		
BRANDON MAJOR CRIME UNIT	S	Z1	✓		✓	✓	✓		
BRANDON MAJOR CRIME UNIT	M	Z1	✓		✓	✓	✓		
GARAGE ZONE 2:									
GARAGE	M	Z2	✓		✓	✓	✓		
GARAGE	HT	Z2	✓		✓	✓	✓		O1
GARAGE	EOL	Z2	✓		✓	✓			
BASEMENT ZONE 3:									
INNER EXHIBIT ROOM	S	Z3	✓		✓	✓	✓		
OUTER EXHIBIT ROOM	RHT	Z3	✓		✓	✓	✓		
KITCHEN	RHT	Z3	✓		✓	✓	✓		
HOLDING TANK / STORAGE ROOM	S	Z3	✓		✓	✓	✓		
MENS WASHROOM	RHT	Z3	✓		✓	✓	✓		
WOMENS WASHROOM	RHT	Z3	✓		✓	✓	✓		
EXERCISE ROOM	M	Z3	✓		✓	✓	✓		
EXERCISE ROOM	S	Z3	✓		✓	✓	✓		
CHANGE ROOM	S	Z3	✓		✓	✓	✓		
MECHANICAL ROOM	HT	Z3	✓		✓	✓	✓		O1
HALL BY KITCHEN	S	Z3	✓		✓	✓	✓		
BY FRONT STAIRS	M	Z3	✓		✓	✓	✓		
OFFICE AT BOTTOM OF STAIRS	RHT	Z3	✓		✓	✓	✓		
JANITORS / MECHANICAL ROOM	RHT	Z3	✓		✓	✓	✓		
WEST STAIRS ZONE 4:									
WEST STAIR	S	Z4	✓		✓	✓	✓		
WEST STAIR	EOL	Z4	✓		✓	✓			

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
EAST STAIRS ZONE 5:									
EAST STAIR	S	Z5	✓		✓	✓	✓		
EAST STAIR	EOL	Z5	✓		✓	✓			
SIGNAL CIRCUIT NAC1:									
GENERAL OFFICE	H/V	NAC1	✓		✓	✓			
OFFICE	H/V	NAC1	✓		✓	✓			
ROOM 13	H/V	NAC1	✓		✓	✓			
BY REAR STAIRS	H/V	NAC1	✓		✓	✓			
BY KITCHEN	H/V	NAC1	✓		✓	✓			
ROOM 14	H/V	NAC1	✓		✓	✓			
ROOM 15	H/V	NAC1	✓		✓	✓			
GARAGE	H/V	NAC1	✓		✓	✓			
GARAGE	EOL	NAC1	✓		✓	✓			

BUILDING NAME:	RCMP BRANDON DETACHMENT	
BUILDING ADDRESS:	SITE 500 BOX 12 RR5 VETERANS WAY BRANDON MB.	
DATE:	WEDNESDAY FEB. 2, 2022	
TEST NG PERFORMED BY:		

Printed Name

Signature

EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service damaged, poor light, battery condition	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, ✗ = Fail	Remarks / Deficiencies / Corrective Action
#1 GENERAL OFFICE WEST WALL	2BP	12V		200W		✓	✓		30	✓	EDWARDS 12EDW200C2-9WT 2-12V 12AH BATTER ES.
BY FACP	RH2					✓	✓			✓	
BY FACP	ES							✓		✓	
OFFICE	RH2					✓	✓			✓	
OFFICE	ES							✓		✓	
OFFICE	RH2					✓	✓			✓	
OFFICE	ES							✓		✓	
BY STORAGE ROOM	ES							✓		✓	
#2 GARAGE EXIT	2BP	12V		100W		✓	✓		30	✓	BEGHELLI NV6100/0 2-6V 12AH BATTERIES.
	ES							✓		✓	
#3 BY REAR EXIT	2BP	6V		50W		✓	✓		30	✓	LUMACELL RG50 BATTERIES 2-6V 7 2AH.
BY STAIRWELL	RH2					✓	✓			✓	
BY REAR EXIT	ES							✓		✓	
#4 BASEMENT	2BP	6V		50W		✓	✓		30	✓	LUMACELL RG50 1-6V 12AH BATTERY.
STA RS	RH2					✓	✓			✓	
KITCHEN	RH2					✓	✓			✓	
ROOM 2	RH2					✓	✓			✓	
ROOM 3	RH2					✓	✓			✓	
ROOM 3	ES							✓		✓	