

BUILDING NAME:	RCMP HAMIOTA DETACHMENT
BUILDING ADDRESS:	14-4TH ST. S/E HAMIOTA MB.
DATE:	TUESDAY MARCH 22 2022

C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
LOCAL SMOKE ALARMS :									
SOUTH GENERAL OFFICE	SA	KIDDIE	✓		✓				O1
NORTH GENERAL OFFICE	SA	KIDDIE	✓		✓				O1

BUILDING NAME:	RCMP HAMIOTA DETACHMENT	
BUILDING ADDRESS:	14-4TH ST. S/E HAMIOTA MB.	
DATE:	TUESDAY MARCH 22 2022	
TEST NG PERFORMED BY:		

Printed Name

Signature

EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service damaged, poor, or light battery condition	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, ✗ = Fail	Remarks / Deficiencies / Corrective Action
SOUTH GENERAL OFFICE	2BP	6V		36W		✓	✓		30	✓	LUMACELL MR16. BATTERY 1-6V 7.2AH.