C3 FIELD DEVICE RECORD

(Reference: Clause 6.1 6)

C6.1 FIELD DEVICE TESTING - LEGEND & NOTES

(Reference: Clauses 6.7.4.1.3, 6.7.4.1.4, 6.7.4.1.5, 6.7.4.3.1, 6.7.4.5.1, 6.7.8.1.1, 6.7.8.2.2, 6.7.8.2.4)

DEVICE	DESCRIPTION	MANUFACTURER	MODEL NO.
M	Manual Station		
M2	Manual Station		
M3	Manual Station		
RHT	Rate of Rise Heat Detector		
RHT2	Rate of Rise Heat Detector		
RHT3	Rate of Rise Heat Detector		
HT	Fixed Temperature Heat Detector		
HT2	Fixed Temperature Heat Detector		
HT3	Fixed Temperature Heat Detector		
	Smoke Detector		
	Sensitivity Test Method:		
S	Conclusity root mounds.		
	Sensitivity Range:	1	
	Constantly Hange.		
	Smoke Detector		
	Sensitivity Test Method:		
S2	Constantly rest meaned.		
	Sensitivity Range:	1	
	Smoke Detector		
	Sensitivity Test Method:		
S3	,		
	Sensitivity Range:	1	
RI	Remote Indicator		
DS	Duct Smoke Detector		
SFD	Supporting Field Device - Monitor		
SFD2	Supporting Field Device - Monitor		
FD	Sprinkler Flow Switch		
SS	Sprinkler Supervisory Device		
PS	Sprinkler Pressure Device		
IM	Isolation Module		
В	Bell		
B2	Bell		
H/V	Horn/Visual		
H/V2	Horn/Visual		
Н	Horn		
H2	Horn		
V	Visual Signal Device		
V2	Visual Signal Device		
SP	Cone Type Speaker		
SP2	Cone Type Speaker		
HSP	Horn Type Speaker		
AD	Ancillary Device		
AD2	Ancillary Device		
ET	Emergency Telephone		
EOL	End of Line Resistor/Capacitor		
EOL2	End of Line Resistor/Capacitor		
LSA	LOCAL SMOKE ALARMS	KIDDE	

BUILDING NAME:	RCMP MELITA DETACHMENT
BUILDING ADRESS:	7 GOVERNMENT RD. MELITA MB.
DATE:	MONDAY MARCH 21.2022

C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensite/ky, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
FRONT OFFICE	LSA		✓		✓				01
REAR OFFICE	LSA		✓		✓				01

BUILDING NAME:	RCMP MELITA DETACHMENT							
BUILDING ADRESS:	7 GOVERNMENT RD. MELITA MB.							
DATE:	MONDAY MARCH 21,2022							
TEST NG PERFORMED BY:								

Printed Name Signature

EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head,		Head,	2BP = BF	w/ 2 Hea	ds, CF	CP = Combo Pack,			ingle Ren	note Head	l, RH2 = Dual Remote Head, ES = Exit Sign
Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service damaged, pilot light, battery condition	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result < = Pass, x=Fail	Remarks / Deficiencies / Corrective Action
SOUTH OFFICE	1BP	6V		36W		✓	✓		30	✓	DUAL LITE CDL-36 1-6V 5AH BATTERY.
NORTH OFFICE	RH1					✓	✓			✓	