

(Reference: Clause 6.1 6)

(Reference: Clauses 6.7.4.1.3, 6.7.4.1.4, 6.7.4.1.5, 6.7.4.3.1, 6.7.4.5.1, 6.7.8.1.1, 6.7.8.2.2, 6.7.8.2.4)

CAN/ULC-S537-13 Appendix C

BUILDING NAME:	RCMP OXFORD HOUSE DETACHMENT
BUILDING ADDRESS:	OXFORD HOUSE MB.
DATE:	OCT. 6,2021

C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
MAIN ENTRANCE	FACP	EDWARDS8616	✓	x	✓	✓	✓		D4,D5,O1,R1
CELL AREA DESK	ANN	EST	✓		✓	✓	✓		
SIGNALS:									
BSMT.:									
GYM BY WASHROOMS	B	NAC1	✓		✓				
GYM BY WASHROOMS	V	NAC2	✓		✓				
GYM BY WASHROOMS	EOL	NAC2	✓						
MECHANICAL ROOM	B	NAC1	✓		✓				
MECHANICAL ROOM	V	NAC2	✓		✓				
HALL	B	NAC1	✓		✓				
MENS CHANGEROOM	V	NAC2	✓		✓				
MENS WASHROOM	V	NAC2	✓		✓				
WOMANS CHANGEROOM	V	NAC2	✓		✓				
WOMANS WASHROOM	V	NAC2	✓		✓				
CRAWLSPACE	V	NAC2	✓		✓				
MAIN FLOOR:									
CELL AREA	B	NAC1	✓		✓				
CELL AREA	V	NAC2	✓		✓				
GARAGE 1	B	NAC1	✓		✓				
OFFICE	B	NAC1	✓		✓				
OFFICE	V	NAC2	✓		✓				
BY CELL 5	V	NAC2	✓		✓				
GARAGE 2	B	NAC1	✓		✓				
DEVICES:									
ATTIC :									
ATTIC	RHT	Z1	✓		✓	✓			
ATTIC	RHT	Z1	✓		✓	✓			
ATTIC STORAGE	RHT2	Z1	✓		✓	✓			
ATTIC	EOL	Z1	✓						
GARAGE:									
GARAGE 1	M	Z2	✓	x	✓	✓			D1
GARAGE 1	HT	Z2	✓	x	✓	✓			D3,O2
GARAGE1	HT	Z2	✓	x	✓	✓			D3,O2
GARAGE 2	M2	Z2	✓		✓	✓			
GARAGE 2	HT	Z2	✓	x	✓	✓			D3,O2
GARAGE 2	HT	Z2	✓	x	✓	✓			D3,O2
GARAGE 2	EOL	Z2	✓						
MAIN FLOOR:									

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
REAR EXIT	M2	Z3	✓		✓	✓			
REAR EXIT	S	Z3	✓	x	✓	✓			D2
JANITORS ROOM	RHT	Z3	✓		✓	✓			
WASHROOM	S	Z3	✓	x	✓	✓			D2
OFFICE HALL BY WASHROOM	S2	Z3	✓	x	✓	✓			D2
REAR OFFICE	S2	Z3	✓	x	✓	✓			D2
FRONT OFFICE	S	Z3	✓	x	✓	✓			D2
OFFICE 2	RHT	Z3	✓		✓	✓			
OFFICE 1	RHT	Z3	✓		✓	✓			
OUTER EVIDENCE ROOM	S	Z3	✓	x	✓	✓			D2
INNER EVIDENCE ROOM	S	Z3	✓	x	✓	✓			D2
MAIN ENTRANCE	M2	Z3	✓		✓	✓			
INTERVIEW ROOM	S	Z3	✓	x	✓	✓			D2
KITCHEN	RHT	Z3	✓		✓	✓			
STAIRS	S	Z3	✓	x	✓	✓			D2, O4
KITCHEN	EOL	Z3	✓						
CELL AREA:									
EXIT TO OFFICE	M	Z4	✓		✓	✓			
FINGERPRINT ROOM	S2	Z4	✓	x	✓	✓			D2
GUARDS DESK	S2	Z4	✓	x	✓	✓			D2
BY EYE WASH STATION	S2	Z4	✓	x	✓	✓			D2
GUARDS WASHROOM	RHT	Z4	✓		✓	✓			
HALL BY CELL 2	S2	Z4	✓	x	✓	✓			D2
HALL BY CELL 4	S2	Z4	✓	x	✓	✓			D2
INTERVIEW ROOM	S2	Z4	✓	x	✓	✓			D2
LAUNDRY ROOM	RHT	Z4	✓		✓	✓			
EXIT TO GARAGE	M	Z4	✓		✓	✓			
PIPECHASE 1-2	S	Z4	✓	x	✓	✓			D2
PIPECHASE 3-4	S	Z4	✓	x	✓	✓			D2
PIPECHASE 5	S	Z4	✓	x	✓	✓			D2
HALL BY CELL 5	M	Z4	✓		✓	✓			
PIPECHASE 1-2	EOL	Z4	✓						
BASEMENT:									
BOTTOM OF STAIRS	M2	Z5	✓		✓	✓			
HALL	S	Z5	✓	x	✓	✓			D2
GYM BY WASHROOMS	RHT	Z5	✓		✓	✓			
GYM BY WASHROOMS	RHT	Z5	✓		✓	✓			
STORAGE ROOM	RHT	Z5	✓		✓	✓			
GYM	RHT	Z5	✓		✓	✓			
GYM	RHT	Z5	✓		✓	✓			
ELECTRICAL ROOM	RHT	Z5	✓		✓	✓			
WATER ROOM	RHT	Z5	✓		✓	✓			
ELECTRICAL ROOM	EOL	Z5	✓						
CELL 5	S3	Z6	✓	x	✓	✓			D2,O5
PIPECHASE 5	EOL		✓						
CELL 4	S3	Z7	✓	x	✓	✓			D2,O5

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
PIPECHASE 3-4	EOL	Z7	✓						
CELL 3	S3	Z8	✓	x	✓	✓			D2,O5
PIPECHASE 3-4	EOL	Z8	✓						
CELL 2	S3	Z9	✓	x	✓	✓			D2,O5
PIPECHASE 1-2	EOL	Z9	✓						
CELL 1	S3	Z10	✓	x					D2,O3,O5
PIPECHASE 1-2	EOL	Z10	✓						

