

C3 FIELD DEVICE RECORD

(Reference: Clause 6.1 6)

C6.1 FIELD DEVICE TESTING - LEGEND & NOTES

(Reference: Clauses 6.7.4.1.3, 6.7.4.1.4, 6.7.4.1.5, 6.7.4.3.1, 6.7.4.5.1, 6.7.8.1.1, 6.7.8.2.2, 6.7.8.2.4)

DEVICE	DESCRIPTION	MANUFACTURER	MODEL NO.
M	Manual Station	EDWARDS	270-SPOE
M2	Manual Station	EDWARDS	
M3	Manual Station		
RHT	Rate of Rise Heat Detector	SYSTEM SENSOR	5601A
RHT2	Rate of Rise Heat Detector		281C
RHT3	Rate of Rise Heat Detector		CR135
HT	Fixed Temperature Heat Detector		
HT2	Fixed Temperature Heat Detector		
HT3	Fixed Temperature Heat Detector		
S	Smoke Detector	MIRCOM	C2W-BA
	Sensitivity Test Method:		
	Sensitivity Range:		
S2	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
S3	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
RI	Remote Indicator		
DS	Duct Smoke Detector		
SFD	Supporting Field Device - Monitor		
SFD2	Supporting Field Device - Monitor		
FD	Sprinkler Flow Switch		
SS	Sprinkler Supervisory Device		
PS	Sprinkler Pressure Device		
IM	Isolation Module		
B	Bell	EDWARDS	439D-6AWC
B2	Bell		
H/V	Horn/Visual		
H/V2	Horn/Visual		
H	Horn		
H2	Horn		
V	Visual Signal Device		
V2	Visual Signal Device		
SP	Cone Type Speaker		
SP2	Cone Type Speaker		
HSP	Horn Type Speaker		
AD	Ancillary Device		
AD2	Ancillary Device		
ET	Emergency Telephone		
EOL	End of Line Resistor/Capacitor		EOL-P1
EOL2	End of Line Resistor/Capacitor		

BUILDING NAME:	RCMP BEAUSEJOUR DETACHMENT
BUILDING ADDRESS:	652 GERTRUDE AVE. BEAUSEJOUR MB.
DATE:	WEDNESDAY JANUARY 5,2022

C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
MAIN FRONT ENTRANCE	FACP	MIRCOM FA-100BK	✓		✓	✓	✓		O1
DEVICES :									
BASEMENT :									
MAIN ROOM CENTRE	RHT2	Z1	✓		✓	✓	✓		
S/E STORAGE ROOM	RHT3	Z1	✓		✓	✓	✓		
COLD STORAGE ROOM	RHT	Z1	✓		✓	✓	✓		
TOP OF BASEMENT STAIRS	S	Z1	✓		✓	✓	✓	2.6%	
2ND FLOOR :									
TOP OF STAIRS	S	Z1	✓		✓	✓	✓	2.6%	
WEIGHT ROOM	RHT2	Z1	✓		✓	✓	✓		
LOCKER ROOM	RHT2	Z1	✓		✓	✓	✓		
MAIN FLOOR :									
CELL AREA HALL	S	Z1	✓		✓	✓	✓	2.4%	
OUTER EXHIBIT ROOM	S	Z1	✓		✓	✓	✓	2.4%	
CELL AREA HALL EXIT	M	Z1	✓		✓	✓	✓		
CELL 1	S	Z1	✓		✓	✓	✓	2.4%	O2
CELL 2	S	Z1	✓		✓	✓	✓	2.4%	O2
FINGERPRINT / BREATHALIZER ROOM	S	Z1	✓		✓	✓	✓	2.6%	
JANITORS CLOSET	RHT	Z1	✓		✓	✓	✓		
HALL EXIT BY WASHROOMS	M	Z1	✓		✓	✓	✓		
INNER EXHIBIT ROOM	S	Z1							O3
HALL BY OPERATIONS N/O OFFICE	S	Z1	✓		✓	✓	✓	2.4%	
BY FRONT EXIT	M	Z1	✓		✓	✓	✓		
HALL BY BOARDROOM	S	Z1	✓		✓	✓	✓	2.4%	
EXIT BY BOARDROOM	M2	Z1	✓		✓	✓	✓		
BOARDROOM	RHT2	Z1	✓		✓	✓	✓		
PROJECTS OFFICE S/E OF BOARDROOM	RHT2	Z1	✓		✓	✓	✓		
INTERVIEW ROOM	S	Z1	✓		✓	✓	✓	2.6%	
FILES ROOM	S	Z1	✓		✓	✓	✓	2.4%	
KITCHEN	RHT2	Z1	✓		✓	✓	✓		
BY KITCHEN EXIT	M2	Z1	✓		✓	✓	✓		
BY KITCHEN EXIT	S	Z1	✓		✓	✓	✓	2.4%	
ROOM 10	EOL	Z1	✓						
CRAWLSPACE ZONE 2 :									
N/E	RHT	Z2	✓		✓	✓	✓		O4
N/W	RHT	Z2	✓		✓	✓	✓		O4
S/E	RHT	Z2	✓		✓	✓	✓		
CRAWLSPACE	EOL	Z2	✓						
SIGNALS :									
BASEMENT	B	NAC1	✓		✓				439D-6AWC

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
OFFICE HALL	B	NAC1	✓		✓				439D-6AWC
CELL AREA HALL	B	NAC1	✓		✓				439D-6AWC
HALL BY BOARDROOM	B	NAC1	✓		✓				439D-6AWC
2ND FLOOR HALL	B	NAC1	✓		✓				439D-6AWC
2ND FLOOR HALL	EOL	NAC1	✓						

BUILDING NAME:	RCMP BEAUSEJOUR DETACHMENT	
BUILDING ADDRESS:	652 GERTRUDE AVE. BEAUSEJOUR MB.	
DATE:	WEDNESDAY JANUARY 5, 2022	
TEST NG PERFORMED BY:		

Printed Name

Signature

EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service (damaged, poor light, battery condition)	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, ✗ = Fail	Remarks / Deficiencies / Corrective Action
BASEMENT BOTTOM OF STAIRS	2BP	6V		100W		✓	✓		30	✓	BEGHELLI NV6-100-2. BATTERIES 2-6V 12AH.
2ND FLOOR STAIRWELL	RH2					✓	✓			✓	
CONFERENCE ROOM	RH1					✓	✓			✓	
KITCHEN EXIT :	2BP	6V		36W		✓	✓		30	✓	LUMACELL RG36/LMC. BATTERY 1-6V 7.2AH.
	ES					✓		✓		✓	
HALL EXIT BY BOARDROOM	2BP	6V		36W		✓	✓		30	✓	LUMACELL RG36/LMC. BATTERY 1-6V 7.2AH.
	ES					✓		✓		✓	
OUTER EXHIBIT ROOM	BP	12V		160W		✓			30	✓	DUAL LITE C12AS-160-BC1. BATTERIES 3-12V 12AH.
CELL AREA HALL	ES					✓		✓		✓	
CELL AREA HALL	RH1					✓	✓			✓	
HALL BY WASHROOMS	RH2					✓	✓			✓	
BY WASHROOM HALL	ES					✓		✓		✓	
GENERAL OFFICE EXIT	ES					✓		✓		✓	
MAIN EXIT	ES					✓		✓		✓	
RECEPTION AREA	RH1					✓	✓			✓	
GENERAL OFFICE HALL	RH2					✓	✓			✓	