

C3 FIELD DEVICE RECORD

(Reference: Clause 6.1 6)

C6.1 FIELD DEVICE TESTING - LEGEND & NOTES

(Reference: Clauses 6.7.4.1.3, 6.7.4.1.4, 6.7.4.1.5, 6.7.4.3.1, 6.7.4.5.1, 6.7.8.1.1, 6.7.8.2.2, 6.7.8.2.4)

DEVICE	DESCRIPTION	MANUFACTURER	MODEL NO.
M	Manual Station	EDWARDS	270-SPO
M2	Manual Station		
M3	Manual Station		
RHT	Rate of Rise Heat Detector	EST	SIGA-
RHT2	Rate of Rise Heat Detector		
RHT3	Rate of Rise Heat Detector		
HT	Fixed Temperature Heat Detector		
HT2	Fixed Temperature Heat Detector		
HT3	Fixed Temperature Heat Detector		
S	Smoke Detector	EST	SIGA-PD
	Sensitivity Test Method:		
	Sensitivity Range:		
S2	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
S3	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
RI	Remote Indicator		
DS	Duct Smoke Detector	EST	SIGA-SD
SFD	Supporting Field Device - Monitor		
SFD2	Supporting Field Device - Monitor		
FD	Sprinkler Flow Switch		
SS	Sprinkler Supervisory Device		
PS	Sprinkler Pressure Device		
IM	Isolation Module		
B	Bell		
B2	Bell		
H/V	Horn/Visual	EST	
H/V2	Horn/Visual		
H	Horn		
H2	Horn		
V	Visual Signal Device	EST	
V2	Visual Signal Device		
SP	Cone Type Speaker		
SP2	Cone Type Speaker		
HSP	Horn Type Speaker		
AD	Ancillary Device		
AD2	Ancillary Device		
ET	Emergency Telephone		
EOL	End of Line Resistor/Capacitor		
EOL2	End of Line Resistor/Capacitor		

BUILDING NAME:	RCMP LITTLE GRAND RAPIDS DETACHMENT
BUILDING ADDRESS:	C.P. 39 LITTLE GRAND RAPIDS MB.
DATE:	Wednesday, June 22, 2022

C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
MAIN FRONT ENTRANCE	FACP	QUICKSTART	✓	x	✓	✓	✓		D1.
MAIN FRONT ENTRANCE	BPS	BPS6AC	✓	x	✓	✓	✓		D2
MEMBERS ENTRANCE	ANN	QUICKSTART	✓		✓	✓	✓		
CELL AREA DESK	ANN	QUICKSTART	✓		✓	✓	✓		
LOOP ISOLATORS:									
BY CELL 1	IM	01 01 022	✓		✓	✓			
BY CELL 2	IM	01 01 024	✓		✓	✓			
BY CELL 3	IM	01 01 026	✓		✓	✓			
BY CELL 4	IM	01 01 028	✓		✓	✓			
BY CELL 5	IM	01 01 030	✓		✓	✓			
ROOM 119	IM	01 01 046	✓		✓	✓			
ROOM 120	IM	01 01 048	✓		✓	✓			
ROOM 140	IM	01 01 037	✓		✓	✓			
ROOM 126	IM	01 01 036	✓		✓	✓			
ROOM 109	IM	01 01 058	✓		✓	✓			
ROOM 110	IM	01 01 056	✓		✓	✓			
SIGNALS:									
BY PUBLIC WASH ROOM	H/V		✓		✓	✓			
MONITORING ROOM	H/V		✓		✓	✓			
INTERVIEW ROOM	H/V		✓		✓	✓			
KITCHEN/STAFF ROOM	V		✓		✓	✓			
HALLWAY	V		✓		✓	✓			
MENS CHANGE ROOM	V		✓		✓	✓			
HALLWAY	H/V		✓		✓	✓			
EXERCISE ROOM	V		✓		✓	✓			
WOMANS CHANGE ROOM	V		✓		✓	✓			
HALL BY JANITORS ROOM	H		✓		✓	✓			
HALL	H/V		✓		✓	✓			
OUTSIDE	H		✓		✓	✓			
OUTSIDE	H		✓		✓	✓			
HALL BY CELL 1	H/V		✓		✓	✓			
HALL BY GUARDS DESK	H/V		✓		✓	✓			
BY GARAGE	H/V		✓		✓	✓			
GARAGE	H/V		✓		✓	✓			
INTERVIEW ROOM 2	V		✓		✓	✓			
GUARDS WASHROOM	V		✓		✓	✓			
DEVICES :									
UNSECURE CRAWLSPACE:									
CENTRE NORTH	RHT	01 01 001	✓		✓	✓	✓		O1

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
CENTRE	RHT	01 01 002	✓		✓	✓	✓		O1
CENTRE SOUTH	RHT	01 01 003	✓		✓	✓	✓		O1
SOUTH	RHT	01 01 004	✓		✓	✓	✓		O1
NORTH	RHT	01 01 010	✓		✓	✓	✓		O1
SECURE CRAWLSPACE:									
SOUTH	RHT	01 01 005	✓		✓	✓	✓		O1
CENTRE SOUTH	RHT	01 01 006	✓		✓	✓	✓		O1
CENTRE	RHT	01 01 007	✓		✓	✓	✓		O1
CENTRE NORTH	RHT	01 01 008	✓		✓	✓	✓		O1
NORTH	RHT	01 01 009	✓		✓	✓	✓		O1
OFFICE:									
KITCHEN/STAFF ROOM 104	S	01 01 011	✓		✓	✓	✓		
MAIN OFFICE AREA NORTH ROOM 106	S	01 01 012	✓		✓	✓	✓		
MAIN OFFICE AREA SOUTH ROOM 106	S	01 01 061	✓		✓	✓	✓		
MAIN ENTRANCE	M	01 01 137	✓		✓	✓	✓		
LOBBY WASHROOM	S	01 01 064	✓		✓	✓	✓		
TELEPHONE CLOSET ROOM 112	S	01 01 059	✓		✓	✓	✓		
ROOM 105	S	01 01 060	✓		✓	✓	✓		
ROOM 108	S	01 01 062	✓		✓	✓	✓		
ROOM 111	S	01 01 054	✓		✓	✓	✓		
ROOM 110	S	01 01 055	✓		✓	✓	✓		
ROOM 109	S	01 01 057	✓		✓	✓	✓		
LAN ROOM 114	S	01 01 053	✓		✓	✓	✓		
HALL BY LAN ROOM	S	01 01 051	✓		✓	✓	✓		
STORAGE ROOM 115	RHT	01 01 052	✓		✓	✓	✓		
SOUTH EXIT	M	01 01 134	✓		✓	✓	✓		
HALL BY CHANGE ROOMS	S	01 01 049	✓		✓	✓	✓		
MENS CHANGE ROOM 119	RHT	01 01 043	✓		✓	✓	✓		
WOMENS CHANGE ROOM 120	RHT	01 01 044	✓		✓	✓	✓		
JANITORS ROOM 117	RHT	01 01 050	✓		✓	✓	✓		
MECHANICAL ROOM 118	S	01 01 034	✓		✓	✓	✓		
CELL AREA:									
CELL 1	S	01 01 021	✓		✓	✓	✓		
CELL 2	S	01 01 023	✓		✓	✓	✓		
CELL 3	S	01 01 025	✓		✓	✓	✓		
CELL 4	S	01 01 027	✓		✓	✓	✓		
CELL 5	S	01 01 029	✓		✓	✓	✓		
NORTH HALL EXIT	M	01 01 127	✓		✓	✓	✓		
HALL BY CELL 4	S	01 01 018	✓		✓	✓	✓		
LAUNDRY ROOM 130	RHT	01 01 014	✓		✓	✓	✓		
MOP ROOM 129	RHT	01 01 015	✓		✓	✓	✓		
LOCKER ROOM 128	RHT	01 01 016	✓		✓	✓	✓		
ROOM 127	RHT	01 01 017	✓		✓	✓	✓		
GUARDS AREA EXIT	M	01 01 130	✓		✓	✓	✓		
PIPECHASE BY CELL 1	RHT	01 01 065	✓		✓	✓	✓		
PIPECHASE BY CELL 3	RHT	01 01 019	✓		✓	✓	✓		
PIPECHASE BY CELL 5	RHT	01 01 031	✓		✓	✓	✓		
SECURE SHOWER ROOM	S	01 01 032	✓		✓	✓	✓		
GUARDS HALL NORTH	S	01 01 020	✓		✓	✓	✓		
GUARDS WASH ROOM 139	S	01 01 033	✓		✓	✓	✓		

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
GUARDS AREA N/E	S	01 01 038	✓		✓	✓	✓		
INTERVIEW ROOM 141	S	01 01 039	✓		✓	✓	✓		
CAMERA ROOM 142	S	01 01 040	✓		✓	✓	✓		
GUARDS STATION S/W	S	01 01 041	✓		✓	✓	✓		
OUTSIDE ELECTRICAL ROOM:									
CENTRE ROOM	S	01 01 013	✓		✓	✓	✓		
ENTRANCE	M	01 01 126	✓		✓	✓	✓		
GARAGE:									
GARAGE EXIT DOOR	M	01 01 131	✓		✓	✓	✓		
CENTRE	RHT	01 01 042	✓		✓	✓	✓		
DUCT SMOKES:									
MECHANICAL ROOM UNIT 9 AC-1	DS	01 01 035	✓		✓	✓	✓		
WOMENS WASHROOM ABOVE CEILING	DS	01 01 045	✓		✓	✓	✓		
MENS WASHROOM ABOVE CEILING	DS	01 01 047	✓		✓	✓	✓		
CELL CORRIDOR ABOVE CEILING	DS	01 01 063	✓		✓	✓	✓		

BUILDING NAME:	RCMP LITTLE GRAND RAPIDS DETACHMENT	
BUILDING ADDRESS:	C.P. 39 LITTLE GRAND RAPIDS MB.	
DATE:	Wednesday, June 22, 2022	
TEST NG PERFORMED BY:		

Printed Name

Signature

EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service damaged, no light, battery condition	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, x = Fail	Remarks / Deficiencies / Corrective Action
MONITORING ROOM	2BP	120	12V	200W		✓	✓	✓	30	✓	EMERGI-LITE 12V200W. 4-6V12AH BATTERIES.
BY RECEPTION	RH2					✓	✓			✓	
PUBLIC WASHROOM	RH2				x					x	D4
OFFICE	2BP	120	12V	200W	x					x	D3
INNER EVIDENCE ROOM	RH2				x					x	EMERGI-LITE 12V200W. 4-6V12AH BATTERIES.
OUTER EVIDENCE ROOM	RH2				x					x	
ROOM X	RH2				x					x	
SERVER ROOM	2BP	120	12V	200W	x	✓	✓	✓		x	D3,D4.
HALL BY STORAGE ROOM	RH2					✓	✓			✓	EMERGI-LITE 12V200W. 4-6V12AH BATTERIES.
HALL BY WASHROOM	RH2					✓	✓			✓	
MECHANICAL ROOM	2BP	120	12V	200W	x	✓	✓	✓		x	D3,D4
NORTH OF CELL SHOWER ROOM	RH1					✓	✓			✓	EMERGI-LITE 12V200W. 4-6V12AH BATTERIES.
SOUTH OF CELL SHOWER ROOM	RH1					✓	✓			✓	
GUARDS WASHROOM	RH2					✓	✓			✓	
GARAGE	2BP	120	12V	200W	x					x	D3
BY GUARDS DESK	RH1				x					x	EMERGI-LITE 12V200W. 4-6V12AH BATTERIES.
BY GUARDS DESK	RH1				x					x	
INTERVIEW ROOM WEST	RH1				x					x	
INTERVIEW ROOM EAST	RH1				x					x	D4
DATA MASTER ROOM WEST	RH1				x					x	D4
DATA MASTER ROOM EAST	RH1				x					x	D4
WOMENS WASHROOM	2BP	120	12V	200W		✓	✓	✓		✓	EMERGI-LITE 12V200W. 4-6V12AH BATTERIES.
MENS WASHROOM	RH2					✓	✓			✓	
SOUTH HALL EXIT	RH2				x					x	D4
OUTSIDE ELECTRICAL ROOM	2BP	120	12V	200W	x					x	D3
HALL BY CELL 2 SOUTH	RH2				x					x	EMERGI-LITE 12V200W. 4-6V12AH BATTERIES. D4
HALL BY CELL 2 NORTH	RH2				x					x	D4
SARGENTS OFFICE	2BP	120	12V	200W	x					x	D3
HALL BY PANEL A	RH2					✓	✓			✓	EMERGI-LITE 12V200W. 4-6V12AH BATTERIES.
KITCHEN/STAFF ROOM	RH2					✓	✓			✓	
EXIT/SORTIE SIGNS:											
MAIN OFFICE EXIT	ES					✓		✓		✓	
BY RECEPTION	ES					✓		✓		✓	
BY OFFICE STORAGE ROOM	ES					✓		✓		✓	

EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service damaged, poor light, battery condition	Operation Confirmed	Heads properly aligned	Exit direction Indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, ✗ = Fail	Remarks / Deficiencies / Corrective Action
EXIT TO OFFICE	ES					✓		✓		✓	
GARAGE	ES					✓		✓		✓	
CELL AREA NORTH EXIT	ES					✓		✓		✓	
CELL AREA EXIT TO GARAGE	ES									✗	D5