

### E3. FIELD DEVICE RECORD

(Reference: Clause 5.1 6)

#### E3.1 FIELD DEVICE TESTING - LEGEND & NOTES

(Reference: Clauses 5.7.4.1.3, 5.7.4.1.4, 5.7.4.1.5, 5.7.4.3.1, 5.7.4.5.1, 5.7.8.1.1, 5.7.8.2.2, 5.7.8.2.4)

DEVICE	DESCRIPTION	MANUFACTURER	MODEL NO.
M	Manual Station	EDWARDS	270-SPO
M2	Manual Station	MIRCOM	MS-401
RHT	Rate of Rise Heat Detector		281A / 282A
RHT2	Rate of Rise Heat Detector		CR135
HT	Fixed Temperature Heat Detector		CF135
HT2	Fixed Temperature Heat Detector		
S	Smoke Detector	EST	EDW2151A
	Sensitivity Test Method:		
	Sensitivity Range:		
S2	Smoke Detector	MIRCOM	
	Sensitivity Test Method:		
	Sensitivity Range:		
RI	Remote Indicator		
DS	Duct Smoke Detector	EDWARDS	6360-500 / 6264
SFD	Supporting Field Device - Monitor		
SFD2	Supporting Field Device - Monitor		
FD	Sprinkler Flow Switch		
SS	Sprinkler Supervisory Device		
PS	Sprinkler Pressure Device		
IM	Isolation Module		
B	Bell		6"
B2	Bell		
H/V	Horn/Visual		
H/V2	Horn/Visual		
H	Horn		
H2	Horn		
V	Visual Signal Device		
V2	Visual Signal Device		
SP	Cone Type Speaker		
SP2	Cone Type Speaker		
HSP	Horn Type Speaker		
AD	Ancillary Device		
AD2	Ancillary Device		
ET	Emergency Telephone		
EOL	End of Line Resistor/Capacitor		EOL-P1
EOL2	End of Line Resistor/Capacitor		
RHT3	Rate of Rise Heat Detector		5601A

BUILDING NAME:	RCMP CARMAN DETACHMENT
BUILDING ADDRESS:	215 MAIN ST. CARMAN MB.
DATE:	WEDNESDAY FEB. 10,2021

### C3.2 INDIVIDUAL DEVICE RECORD

(Reference Clauses 5.7.1.3, E3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Annunciation Indication Confirmed	Remarks / Required Additional Readings
FRONT ENTRANCE VESTIBULE	FACP	EDWARDS 0016	✓		✓	✓	
CELL AREA GUARDS DESK	FACP	MIRCOM FA-102A	✓		✓	✓	
CRAWLSPACE ZONE 1 :							
CRAWLSPACE	RHT	Z1	✓		✓	✓	O1
CRAWLSPACE	RHT	Z1	✓		✓	✓	O1
CRAWLSPACE	RHT	Z1	✓		✓	✓	O1
CRAWLSPACE	RHT	Z1	✓		✓	✓	O1
CRAWLSPACE	RHT	Z1	✓		✓	✓	O1
CRAWLSPACE	EOL	Z1	✓				O1
ADMINISTRATION ZONE 2:							
GENERAL OFFICE RECEPTION	M2	Z2	✓		✓	✓	
HALL BY MENS WASHROOM	M	Z2	✓		✓	✓	
JANITORS ROOM	RHT	Z2	✓		✓	✓	
GENERAL OFFICE AREA NORTH	S	Z2	✓		✓	✓	
FILE ROOM	S	Z2	✓		✓	✓	
SOUTH OFFICE EXIT	M	Z2	✓		✓	✓	
SOUTH AREA EXIT	S	Z2	✓		✓	✓	
SOUTH OFFICE BY EXIT	S	Z2	✓		✓	✓	
SOUTH OFFICE WEST	RHT	Z2	✓		✓	✓	
SOUTH AREA EXIT	EOL	Z2	✓				
SOFT INTERVIEW ROOM	S	Z2	✓		✓	✓	
STAFF ROOM	RHT3	Z2	✓		✓	✓	
OFFICE SUPPLY ROOM	S	Z2	✓		✓	✓	
GENERAL OFFICE AREA SOUTH	S	Z2	✓		✓	✓	
CELL AREA & GARAGE ZONE 3 :							
PRISONER VISITATION VISITORS S DE	S	Z3	✓		✓	✓	
NORTH HALL CELL AREA	S	Z3	✓		✓	✓	
SOUTH HALL CELL AREA	S	Z3	✓		✓	✓	
GUARD DESK AREA	M	Z3	✓		✓	✓	
PRISONER VISITATION PRISONER S DE	S	Z3	✓		✓	✓	
PRISONER LOCKER ROOM	S	Z3	✓		✓	✓	
INNER EVIDENCE ROOM	S	Z3					O3
OUTER EVIDENCE ROOM	S	Z3	✓		✓	✓	
GARAGE 1 / SECURE BAY	M	Z3	✓		✓	✓	
GARAGE 1 / SECURE BAY	RHT	Z3	✓		✓	✓	O1
GYM AT OVERHEAD DOOR	M	Z3	✓		✓	✓	
GYM AT SMALL DOOR	M2	Z3	✓		✓	✓	

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Annunciation Indication Confirmed	Remarks / Required Additional Readings
GYM	RHT	Z3	✓		✓	✓	O1
GARAGE 1 STORAGE ROOM	RHT2	Z3	✓		✓	✓	O1
GYM	EOL	Z3	✓				
ATTIC & MEZZANINE NORTH ZONE 4:							
TOP OF STAIRS	S	Z4	✓		✓	✓	
TOP OF STAIRS	M	Z4		x			D2
STORAGE ROOM	RHT	Z4	✓		✓	✓	
MECHANICAL ROOM	RHT	Z4	✓		✓	✓	
MEZZANINE NORTH	RHT	Z4	✓		✓	✓	
ATTIC NORTH	RHT	Z4	✓		✓	✓	
ATTIC CENTRE	RHT	Z4	✓		✓	✓	
ATTIC SOUTH	RHT	Z4	✓		✓	✓	
TOP OF STAIRS	EOL	Z4	✓				
RETURN AIR NORTH ZONE 5:							
RETURN AIR NORTH	DS	Z5	✓	x	✓	✓	D3
MECHANICAL ROOM	EOL	Z5	✓				
FURNACE 2 ZONE 6:							
FURNACE 2	DS	Z6	✓	x	✓	✓	D3
MECHANICAL ROOM	EOL	Z6	✓				
FURNACE 1 ZONE 7 :							
FURNACE 1	DS	Z7	✓	x	✓	✓	D3
MECHANICAL ROOM	EOL	Z7	✓				
CELL DEVICES ZONE 8 :							
CELL 1	S	Z8-1	✓	x	✓	✓	D1
FINGERPRINT ROOM	S	Z8-3	✓	x	✓	✓	D1
CELL 2	S	Z8-2	✓	x	✓	✓	D1
HARD INTERVIEW ROOM	S	Z8-4	✓	x	✓	✓	D1
2ND FLOOR SOUTH AREA ZONE 9:							
LADIES CHANGE ROOM	M	Z9	✓		✓	✓	
LADIES CHANGE ROOM	RHT2	Z9	✓		✓	✓	
MECHANICAL ROOM	RHT	Z9	✓		✓	✓	
TOP OF STAIRS	S	Z9	✓		✓	✓	
SUPPLY AIR SOUTH ZONE 10 :							
SUPPLY AIR SOUTH	DS	Z10	✓	x	✓	✓	D1
SOUTH MECHANICAL ROOM	EOL	Z10	✓				
RETURN AIR SOUTH ZONE 11:							
RETURN AIR SOUTH	DS	Z11	✓	x	✓	✓	D1
SOUTH MECHANICAL ROOM	EOL	Z11	✓				
FAN 1	AD		✓		✓	✓	
FAN 2	AD		✓		✓	✓	
FAN 3	AD		✓		✓	✓	

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Annunciation Indication Confirmed	Remarks / Required Additional Readings
SIGNALS :							
ROOM 17	B	NAC1	✓		✓		
ROOM 18	B	NAC1	✓		✓		
GENERAL ROOM	B	NAC1	✓		✓		
MAIN FLOOR SOUTH	B	NAC1	✓		✓		
2ND FLOOR SOUTH	EOL	NAC2	✓				
2ND FLOOR SOUTH	B	NAC2	✓		✓		
MECHANICAL MEZZANINE	B	NAC1	✓		✓		
MECHANICAL MEZZANINE	EOL	NAC1	✓				
ATTIC	B	NAC1	✓		✓		
CELL AREA GUARDS DESK	H	ZONE 8 SIGNAL 1	✓		✓		

BUILDING NAME:	RCMP CARMAN DETACHMENT	
BUILDING ADDRESS:	215 MAIN ST. CARMAN MB.	
DATE:	WEDNESDAY FEB. 10, 2021	
TEST NG PERFORMED BY:		

Printed Name

Signature

### EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD

Legend: BP = Battery Pack, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service damaged, no light, battery condition	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, x=Fail	Remarks / Deficiencies / Corrective Action
GENERAL OFFICE JANITORS CLOSET	CP	12V		360W		✓	✓	✓	30	✓	EDWARDS / 12EDW360C2-9WT. BATTERY 1-12V 35AH.
GENERAL OFFICE ENTRANCE	ES					✓		✓		✓	
GENERAL OFFICE N/E	RH1					✓	✓			✓	
GENERAL OFFICE N/W	RH2					✓	✓			✓	
OFFICE SOUTH HALL	ES					✓		✓		✓	
OFFICE SOUTH HALL	RH1				x					x	D4
2ND FLOOR SOUTH LADIES CHANGE ROOM	CP	12V		200W		✓	✓		30	✓	EDWARDS / 12EDW200C2-9WT. BATTERIES 2-12V 7.2AH.
BOTTOM OF STAIRWELL	ES					✓		✓		✓	
SOUTH OFFICE MAIN FLOOR	RH2					✓	✓			✓	
SOUTH STAIRWELL	RH2					✓	✓			✓	
SOUTH OFFICE EXIT	ES					✓		✓		✓	
2ND FLOOR NORTH ROOM	CP	12V		360W		✓	✓		30	✓	BEGHELLI / NV12360/0. BATTERY 1-12V 35AH.
CELL HALL SOUTH EXIT	ES					✓		✓		✓	
CELL HALL NORTH EXIT	ES					✓		✓		✓	
GARAGE	ES					✓		✓		✓	
2ND FLR. NORTH ROOM TO MECHANICAL ROOM	ES					✓		✓		✓	
CELL AREA GUARDS ROOM	RH2					✓	✓			✓	
CELL HALL BY CELL 1	RH1					✓	✓			✓	
CELL HALL BY GUARDS ROOM	RH1					✓	✓			✓	
CELL HALL BY GARAGE	RH1					✓	✓			✓	
GARAGE	RH1					✓	✓			✓	
GYM	CP	12V		360W	x					x	D5. BEGHELLI / NV12360/0. BATTERY 1-12V 35AH.
2ND FLOOR MECHANICAL ROOM	CP	12V		160W		✓	✓		30	✓	DUAL LITE / C12AS-160-BCI. BATTERIES 3-12V 12AH.
MECHANICAL ROOM EXIT TO NORTH ROOM	ES					✓		✓		✓	
MECHANICAL ROOM EXIT TO NORTH ROOM	RH2					✓	✓			✓	
MECHANICAL ROOM EXIT TO HALL	ES					✓		✓		✓	
SOUTH STAIRWELL	RH1				x					x	D6.