

E3. FIELD DEVICE RECORD

(Reference: Clause 5.1.6)

E3.1 FIELD DEVICE TESTING - LEGEND & NOTES

(Reference: Clauses 5.7.4.1.3, 5.7.4.1.4, 5.7.4.1.5, 5.7.4.3.1, 5.7.4.5.1, 5.7.8.1.1, 5.7.8.2.2, 5.7.8.2.4)

DEVICE	DESCRIPTION	MANUFACTURER	MODEL NO.
M	Manual Station	EDWARDS	270-SPO
M2	Manual Station	MIRCOM	MS-710
M3	Manual Station		
RHT	Rate of Rise Heat Detector		
RHT2	Rate of Rise Heat Detector		
RHT3	Rate of Rise Heat Detector		
HT	Fixed Temperature Heat Detector	EDWARDS	283A
HT2	Fixed Temperature Heat Detector		
HT3	Fixed Temperature Heat Detector		
S	Smoke Detector	EST	C2M-PD1
	Sensitivity Test Method:		
	Sensitivity Range:		
S2	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
S3	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
RI	Remote Indicator		
DS	Duct Smoke Detector	EST	SD-2W
SFD	Supporting Field Device - Monitor		
SFD2	Supporting Field Device - Monitor		
FD	Sprinkler Flow Switch		
SS	Sprinkler Supervisory Device		
PS	Sprinkler Pressure Device		
IM	Isolation Module		
B	Bell		
B2	Bell		
H/V	Horn/Visual	EST	G1-HDVM
H/V2	Horn/Visual		
H	Horn		
H2	Horn		
V	Visual Signal Device		
V2	Visual Signal Device		
SP	Cone Type Speaker		
SP2	Cone Type Speaker		
HSP	Horn Type Speaker		
AD	Ancillary Device		
AD2	Ancillary Device		
ET	Emergency Telephone		
EOL	End of Line Resistor/Capacitor		
EOL2	End of Line Resistor/Capacitor		

BUILDING NAME:	RCMP Morden Detachment
BUILDING ADDRESS:	797 Thornhill St, Morden, MB R6M 1Y6
DATE:	MONDAY, JANUARY 31, 2022

E3.2 INDIVIDUAL DEVICE RECORD

(Reference Clauses 5.7.1.3, E3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
PANEL:								
FRONT MAIN ENTRANCE	FACP		✓		✓	✓		O2
CRAWLSPACE ZONE 3 :								
CRAWLSPACE	HT	3	✓		✓	✓		O1
CRAWLSPACE	HT	3	✓		✓	✓		O1
CRAWLSPACE	HT	3	✓		✓	✓		O1
CRAWLSPACE	HT	3	✓		✓	✓		O1
CRAWLSPACE	HT	3	✓		✓	✓		O1
CRAWLSPACE	EOL	3	✓					
ADMINISTRATION ZONE 2 :								
ENTRANCE	EOL	2	✓					
BY FRONT RECEPTION	M	2	✓		✓	✓		
ENTRANCE	M2	2	✓		✓	✓		
JANITORS ROOM	HT	2	✓		✓	✓		O1
UNDER STAIRS OFF OF MENS WASHROOM	HT	2	✓		✓	✓		O1
GENERAL OFFICE	S	2	✓		✓	✓		
STORAGE ROOM	S	2	✓		✓	✓		
GENERATOR ZONE 8 :								
GENERATOR RUNNING	AD	8	✓		✓	✓		
GENERATOR ZONE 9 :								
GENERATOR TROUBLE	AD	9	✓		✓	✓		
MAIN FLOOR NORTH / GARAGE BAYS ZONE 1 :								
FILE ROOM	S	1	✓		✓	✓		
CELL AREA EAST HALL	S	1	✓		✓	✓		
CELL AREA WEST HALL	S	1	✓		✓	✓		
CELL AREA EAST EXIT TO GARAGE	M	1	✓		✓	✓		
CELL AREA WEST HALL TO GARAGE	M	1	✓		✓	✓		
GARAGE	HT	1	✓		✓	✓		O1
GARAGE EXIT S/W	M	1	✓		✓	✓		
WEIGHT ROOM S/W	M	1	✓		✓	✓		
WEIGHT ROOM	HT	1	✓		✓	✓		O1
TIRE STORAGE ROOM	HT	1	✓		✓	✓		O1
CELL AREA GUARDS ROOM	M	1	✓		✓	✓		
STORAGE ROOM ACROSS FROM GUARDS ROOM	HT	1	✓		✓	✓		O1
WEIGHT ROOM S/W	EOL	1	✓					
EVIDENCE ROOM	S	1	✓		✓	✓		
ATTIC & MEZZANINE ZONE 6 :								
TOP OF STAIRS	M	6	✓		✓	✓		
TOP OF STAIRS	S	6	✓		✓	✓		
STORAGE AREA	HT	6	✓		✓	✓		O1
MECHANICAL ROOM	HT	6	✓		✓	✓		O1
LAN ROOM	HT	6	✓		✓	✓		O1
ATTIC EAST	HT	6	✓		✓	✓		O1
ATTIC WEST	HT	6	✓		✓	✓		O1
TOP OF STAIRS	EOL	6	✓					
CELL AREA ZONE 7 :								
NEW OFFICE NORTH	EOL	7	✓					

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
CELL AREA STORAGE ROOM	S	7	✓		✓	✓		
OCC ROOM NORTH	S	7	✓		✓	✓		
OCC ROOM S/E	S	7	✓		✓	✓		
DUCT SMOKE 1 ZONE 4 :								
MECHANICAL ROOM	DS	4	✓		✓	✓		
MECHANICAL ROOM	EOL	4	✓					
DUCT SMOKE 2 ZONE 5 :								
MECHANICAL ROOM	DS	5	✓		✓	✓		
MECHANICAL ROOM	EOL	5	✓					
SIGNAL NAC 1 :								
MECHANICAL ROOM	H/V	NAC 1	✓		✓	✓		
ATTIC	H/V	NAC 1	✓		✓	✓		
GENERAL OFFICE	H/V	NAC 1	✓		✓	✓		
NORTH OFFICE HALL	H/V	NAC 1	✓		✓	✓		
NORTH OFFICE NORTH STORAGE ROOM	H/V	NAC 1	✓		✓	✓		
OCC ROOM NORTH	H/V	NAC 1	✓		✓	✓		
OCC ROOM S/E	H/V	NAC 1	✓		✓	✓		
ATTIC	EOL	NAC 1	✓					

BUILDING NAME:	RCMP Morden Detachment	
BUILDING ADDRESS:	797 Thornhill St, Morden, MB R6M 1Y6	
DATE:	MONDAY, JANUARY 31, 2022	
TEST NG PERFORMED BY:		

Printed Name

Signature

EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service damaged, poor light, battery condition	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, ✗ = Fail	Remarks / Deficiencies / Corrective Action
MEZZANINE MECHANICAL AREA	2BP	120	6	36		✓	✓		30	✓	LUMACELL RG36 BATTERY 1-6V 7.2AH. O3
MEZZANINE MECHANICAL AREA	2BP	120	12	160		✓	✓		30	✓	DUAL LITE C12AS-160-BCI. BATTERIES 3-12V 12AH. O3
TOP OF STAIRS	RH1					✓	✓				
MEZZANINE STORAGE AREA	ES					✓		✓			
MECHANICAL MEZZANINE	ES					✓		✓			
MECHANICAL STORAGE	RH2					✓	✓				
MECHANICAL STORAGE	ES					✓		✓			
ATTIC	ES					✓		✓			
NEW NORTH OFFICE AREA / OLD CELL AREA GUARDS ROOM	2BP	120	12	160		✓	✓		30	✓	DUAL LITE C12AS-160-BCI. BATTERIES 3-12V 12AH. O3
EAST HALL	RH1					✓	✓			✓	
CENTRE HALL	RH1					✓	✓			✓	
EAST HALL	ES					✓		✓		✓	
WEST HALL	ES					✓		✓		✓	
GARAGE	RH1					✓	✓			✓	
GARAGE SW ES	ES					✓		✓		✓	
JANITORS ROOM	1BP	120	12	160		✓	✓		30	✓	DUAL LITE C12AS-160-BCI. BATTERIES 3-12V 12AH.
BY JANITORS ROOM	RH1					✓	✓			✓	
BY WASHROOM	ES					✓		✓		✓	
BY WEST ES	ES					✓		✓		✓	
FRONT RECEPTION	ES					✓		✓		✓	
GENERAL OFFICE	RH1					✓	✓			✓	
GENERAL OFFICE COMPUTOR AREA	RH1					✓	✓			✓	
EMERGENCY CONTROL ROOM 1	2BP	120	12	360		✓	✓		30	✓	A MLITE EBST12360. BATTERY 1-12V 35AH. O3
EMERGENCY CONTROL ROOM 2	2BP	120	12	360		✓	✓		30	✓	AIMLITE EBST12360. BATTERY 1-12V 35AH. O3
EMERGENCY CONTROL ROOM 3	2BP	120	12	360		✓	✓		30	✓	AIMLITE EBST12360. BATTERY 1-12V 35AH. O3