

### C3 FIELD DEVICE RECORD

(Reference: Clause 6.1.6)

### C6.1 FIELD DEVICE TESTING - LEGEND & NOTES

(Reference: Clauses 6.7.4.1.3, 6.7.4.1.4, 6.7.4.1.5, 6.7.4.3.1, 6.7.4.5.1, 6.7.8.1.1, 6.7.8.2.2, 6.7.8.2.4)

DEVICE	DESCRIPTION	MANUFACTURER	MODEL NO.
M	Manual Station	MIRCOM	MS-402AP
M2	Manual Station		
M3	Manual Station		
RHT	Rate of Rise Heat Detector		
RHT2	Rate of Rise Heat Detector		
RHT3	Rate of Rise Heat Detector		
HT	Fixed Temperature Heat Detector		
HT2	Fixed Temperature Heat Detector		
HT3	Fixed Temperature Heat Detector		
S	Smoke Detector	MIRCOM	
	Sensitivity Test Method:		
	Sensitivity Range:		
S2	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
S3	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
RI	Remote Indicator		
DS	Duct Smoke Detector		
SFD	Supporting Field Device - Monitor		
SFD2	Supporting Field Device - Monitor		
FD	Sprinkler Flow Switch		
SS	Sprinkler Supervisory Device		
PS	Sprinkler Pressure Device		
IM	Isolation Module		
B	Bell		
B2	Bell		
H/V	Horn/Visual		
H/V2	Horn/Visual		
H	Horn		
H2	Horn		
V	Visual Signal Device		
V2	Visual Signal Device		
SP	Cone Type Speaker		
SP2	Cone Type Speaker		
HSP	Horn Type Speaker		
AD	Ancillary Device		
AD2	Ancillary Device		
ET	Emergency Telephone		
EOL	End of Line Resistor/Capacitor		
EOL2	End of Line Resistor/Capacitor		

BUILDING NAME:	RCMP POPLAR RIVER
BUILDING ADDRESS:	POPLAR RIVER MB
DATE:	Thursday, June 2, 2022

### C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
MAIN ENTRANCE	FACP		✓		✓	✓	✓		
CELL AREA GAURDS STATION	ANN		✓		✓	✓	✓		
DETECTION									
OFFICE AREA MAIN FOYER	S	02-001	✓		✓	✓	✓		
EXIBIT RM SECURE EXIBIT RM	S	02-002	✓		✓	✓	✓		
EXIBIT RMS O/N EXIBIT RM	S	02-003	✓		✓	✓	✓		
CELL AREA BREATHALYZER RM	S	02-004	✓		✓	✓	✓		
CELL AREA BY GAURDS STATION	S	02-005	✓		✓	✓	✓		
CELL #1	S	02-006	✓		✓	✓	✓		
CELL AREA CELL CORR.	S	02-007	✓		✓	✓	✓		
CELL #2	S	02-008	✓		✓	✓	✓		
CELL #3	S	02-009	✓		✓	✓	✓		
MAIN ENTRANCE PS	M	02-101	✓		✓	✓	✓		
MAIN ENTRANCE PS	GA	02-102	✓		✓	✓	✓		
CELL AREA GARAGE PS	M	02-103	✓		✓	✓	✓		
CELL AREA GARAGE PS	GA	02-104	✓		✓	✓	✓		
CELL AREA CELL HALLWAY EXIT	M	02-107	✓		✓	✓	✓		
CELL AREA CELL HALLWAY EXIT	GA	02-108	✓		✓	✓	✓		
MAIN SHUTOFF VALVE	TS								O1
BACKFLOW SUPPLY	TS								O1
BACKFLOW DISCHARGE	FS								O1
SIGNALS									
OPEN OFFICE AREA	H	NAC1	✓		✓	✓	✓		
OPEN OFFICE AREA	EOL	NAC1	✓		✓	✓	✓		
CELL AREA CORRIDOR	H	NAC1	✓		✓	✓	✓		
SECURE BAY	H	NAC1	✓		✓	✓	✓		

RCMP POPLAR RIVER	
BUILDING ADDRESS:	POPLAR RIVER MB
DATE:	Thursday, June 2, 2022
TESTING PERFORMED BY:	

Printed Name

Signature

**EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD**

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service damaged, or light battery condition	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, ✗=Fail	Remarks / Deficiencies / Corrective Action
OPEN OFFICE AREA	CP					✓	✓		30	✓	EMERGI-LITE 2 X 6V 7.2AH
MAIN ENTRANCE	RH2					✓	✓		30	✓	
ELEC/MECH RM	RH2					✓	✓		30	✓	
CELL AREA CORR	2BP					✓	✓		30	✓	EMERGI-LITE 2 X 6V 7.2AH
SECURE BAY	2BP					✓	✓		30	✓	EMERGI-LITE 2 X 6V 7.2AH
MA N ENTRANCE	ES					✓		✓	30	✓	
CELL AREA EXIT	ES					✓		✓	30	✓	
SECURE BAY EXIT	ES					✓		✓	30	✓	