

E3. FIELD DEVICE RECORD

(Reference: Clause 5.1 6)

E3.1 FIELD DEVICE TESTING - LEGEND & NOTES

(Reference: Clauses 5.7.4.1.3, 5.7.4.1.4, 5.7.4.1.5, 5.7.4.3.1, 5.7.4.5.1, 5.7.8.1.1, 5.7.8.2.2, 5.7.8.2.4)

DEVICE	DESCRIPTION	MANUFACTURER	MODEL NO.
M	Manual Station	MIRCOM	MS-701
M2	Manual Station		
RHT	Rate of Rise Heat Detector	MIRCOM	
RHT2	Rate of Rise Heat Detector		
HT	Fixed Temperature Heat Detector		
HT2	Fixed Temperature Heat Detector		
S	Smoke Detector	MIRCOM	C2W-BA
	Sensitivity Test Method:		
	Sensitivity Range:		
S2	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
RI	Remote Indicator		
DS	Duct Smoke Detector		
SFD	Supporting Field Device - Monitor		
SFD2	Supporting Field Device - Monitor		
FD	Sprinkler Flow Switch		
SS	Sprinkler Supervisory Device		
PS	Sprinkler Pressure Device		
IM	Isolation Module		
B	Bell		
B2	Bell		
H/V	Horn/Visual		
H/V2	Horn/Visual		
H	Horn	MIRCOM	
H2	Horn		
V	Visual Signal Device		
V2	Visual Signal Device		
SP	Cone Type Speaker		
SP2	Cone Type Speaker		
HSP	Horn Type Speaker		
AD	Ancillary Device		
AD2	Ancillary Device		
ET	Emergency Telephone		
EOL	End of Line Resistor/Capacitor		
EOL2	End of Line Resistor/Capacitor		

BUILDING NAME:	RCMP WINNIPEG LORIMER
BUILDING ADDRESS:	1-996 LORIMER BLVD. WPG. MB.
DATE:	FEB. 10,2022

C3.2 INDIVIDUAL DEVICE RECORD

(Reference Clauses 5.7.1.3, E3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Annunciation Indication Confirmed	Remarks / Required Additional Readings
FRONT ENTRANCE VESTIBULE	FACP	MIRCOM FX-2001-6K	✓		✓	✓	
SIGNALS :							
MAIN ENTRANCE VESTIBULE	H	NAC1	✓		✓	✓	
LUNCH ROOM	H	NAC1	✓		✓	✓	
MEZZANINE OFFICE	H	NAC1	✓		✓	✓	
FRONT WAREHOUSE	H	NAC1	✓		✓	✓	
WAREHOUSE BY ELECTRICAL ROOM	H	NAC1	✓		✓	✓	
WAREHOUSE BY DOORWAY BY LUNCHROOM	H	NAC1	✓		✓	✓	
WAREHOUSE GARAGE	H	NAC1	✓		✓	✓	
DEVICES :							
ZONE 1:							
MAIN ENTRANCE	M	101	✓		✓	✓	
LUNCHROOM EXIT	M	102	✓		✓	✓	
JANITORS ROOM BY LUNCHROOM	RHT	003	✓		✓	✓	
ZONE 2:							
WAREHOUSE UNIT 1 BY GARAGE	RHT	012	✓		✓	✓	
WAREHOUSE UNIT 1 MIDDLE	RHT	013	✓		✓	✓	
WAREHOUSE UNIT 1 BY OFFICE	RHT	014	✓		✓	✓	
WAREHOUSE GARAGE EXIT	M	107	✓		✓	✓	
WAREHOUSE EXIT BY ELECTRICAL ROOM	M	106	✓		✓	✓	
ELECTRICAL ROOM	RHT	005	✓		✓	✓	
WAREHOUSE GARAGE	RHT	008	✓		✓	✓	
WAREHOUSE UNIT 2	RHT	016	✓		✓	✓	
WAREHOUSE UNIT 2	RHT	017	✓		✓	✓	
WAREHOUSE UNIT 2	RHT	018	✓		✓	✓	
ZONE 3:							
TOP OF STAIRS	S	004	✓		✓	✓	
ZONE 4 :							
SERVER ROOM BY ENTRANCE	S	010	✓		✓	✓	
SERVER ROOM BACK	S	009	✓		✓	✓	
TELEPHONE ROOM	RHT	011	✓		✓	✓	
RELAYS:							
DAMPER CONTROL	AD	103	✓		✓		
DOOR RELEASE	AD	104	✓		✓		

