

C3 FIELD DEVICE RECORD

(Reference: Clause 6.1 6)

C6.1 FIELD DEVICE TESTING - LEGEND & NOTES

(Reference: Clauses 6.7.4.1.3, 6.7.4.1.4, 6.7.4.1.5, 6.7.4.3.1, 6.7.4.5.1, 6.7.8.1.1, 6.7.8.2.2, 6.7.8.2.4)

DEVICE	DESCRIPTION	MANUFACTURER	MODEL NO.
M	Manual Station	MIRTONE	73322
M2	Manual Station		
M3	Manual Station		
RHT	Rate of Rise Heat Detector	SYSTEM SENSOR	5601A
RHT2	Rate of Rise Heat Detector		CR135
RHT3	Rate of Rise Heat Detector		CR200
HT	Fixed Temperature Heat Detector		CF135
HT2	Fixed Temperature Heat Detector		
HT3	Fixed Temperature Heat Detector		
S	Smoke Detector	SYSTEM SENSOR	C2W-BA
	Sensitivity Test Method:		
	Sensitivity Range:		
S2	Smoke Detector	EST	6250
	Sensitivity Test Method:		
	Sensitivity Range:		
S3	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
RI	Remote Indicator		
DS	Duct Smoke Detector	SYSTEM SENSOR	D2A & DH100LPA
SFD	Supporting Field Device - Monitor		
SFD2	Supporting Field Device - Monitor		
FD	Sprinkler Flow Switch		
SS	Sprinkler Supervisory Device		
PS	Sprinkler Pressure Device		
IM	Isolation Module		
B	Bell		439D-10AWC
B2	Bell		439D-6AWC
H/V	Horn/Visual		
H/V2	Horn/Visual		
H	Horn		
H2	Horn		
V	Visual Signal Device		
V2	Visual Signal Device		
SP	Cone Type Speaker		
SP2	Cone Type Speaker		
HSP	Horn Type Speaker		
AD	Ancillary Device		
AD2	Ancillary Device		
ET	Emergency Telephone		
EOL	End of Line Resistor/Capacitor		EOL-P1
EOL2	End of Line Resistor/Capacitor		

BUILDING NAME:	RCMP EMERSON DETACHMENT
BUILDING ADDRESS:	352 DALLAS AVE. EMERSON MB.
DATE:	MONDAY MARCH 7,2022

C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
FRONT ENTRANCE VESTIBULE	FACP	MIRCOM FA-204E	✓		✓	✓	✓		O1
DEVICES :									
SIGNALS :									
ROOM 1	B	NAC1	✓		✓	✓			439D-10AWC
ROOM 2	B	NAC1	✓		✓	✓			439D-10AWC
OFFICE	B	NAC2	✓		✓	✓			439D-6AWC
OFFICE AREA	B	NAC2	✓		✓	✓			439D-16AWC
GARAGE	B	NAC2	✓		✓	✓			439D-10AWC
ROOM 2	EOL		✓						EOL-P1
OFFICE AREA ZONE 1 :									
LUNCH ROOM	HT	Z1	✓		✓	✓	✓		CF135. O3
BY LUNCH ROOM	M	Z1	✓		✓	✓	✓		MIRTONE 73322.
GENERAL OFFICE	HT	Z1	✓		✓	✓	✓		CF135. O3
INTERVIEW ROOM	HT	Z1	✓		✓	✓	✓		CF135. O3
CORPORALS OFFICE	HT	Z1	✓		✓	✓	✓		CF135. O3
DSA OFFICE	HT	Z1	✓		✓	✓	✓		CF135. O3
MENS WASHROOM STORAGE	HT	Z1	✓		✓	✓	✓		CF135. O3
BY STAIRS	M	Z1	✓		✓	✓	✓		MIRTONE 73322.
TOP OF STAIRWELL	S	Z1	✓	x	✓	✓	✓		D1. 6250
FILE ROOM	RHT	Z1	✓		✓	✓	✓		5601A
JANITORS ROOM	HT	Z1	✓		✓	✓	✓		CF135. O3
BY STAIRS	EOL	Z1	✓						EOL-P1
CELL AREA ZONE 2 :									
BY GUARDS ROOM IN HALL	S	Z2	✓		✓	✓	✓	2.4%	C2W-BA
EAST HALL	S	Z2	✓		✓	✓	✓	2.4%	C2W-BA
IN GUARDS ROOM	S	Z2	✓		✓	✓	✓	2.4%	C2W-BA
IN GUARDS ROOM	M	Z2	✓		✓	✓	✓		MIRTONE 73322.
PIPECHASE 1-2	HT	Z2	✓		✓	✓	✓		CF135. O3
PIPECHASE 3-4	HT	Z2	✓		✓	✓	✓		CF135. O3
FINGERPRINT ROOM	S	Z2	✓		✓	✓	✓	2.6%	C2W-BA
INNER EXHIBIT ROOM	S	Z2							C2W-BA. O4
OUTER EXHIBIT ROOM	S	Z2	✓		✓	✓	✓	2.4%	C2W-BA.
BASEMENT ZONE 3 :									
BY STAIRS	M	Z3	✓		✓	✓	✓		MIRTONE 73322.
WEIGHT ROOM NORTH	RHT	Z3	✓		✓	✓	✓		5601A
WEIGHT ROOM SOUTH	RHT	Z3	✓		✓	✓	✓		5601A
WEIGHT ROOM BY LOCKERS	RHT	Z3	✓		✓	✓	✓		CR200
MECHANICAL ROOM EAST	HT	Z3	✓		✓	✓	✓		CF135. O3
MECHANICAL ROOM WEST	HT	Z3	✓		✓	✓	✓		CF135. O3
BY STAIRS	EOL	Z3	✓						EOL-P1
CRAWLSPACE ZONE 4 :									

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
CRAWLSPACE ENTRANCE	HT	Z4	✓		✓	✓	✓		CF135. O3
CRAWLSPACE EAST	HT	Z4	✓		✓	✓	✓		CF135. O3
CRAWLSPACE WEST	HT	Z4	✓		✓	✓	✓		CF135. O3
CRAWLSPACE	EOL	Z4	✓						EOL-P1
DUCT DETECTORS ZONE 5 :									
FR-1 RETURN	DS	Z5	✓		✓	✓	✓		D2A
FR-1 SUPPLY	DS	Z5	✓		✓	✓	✓		D2A
FR-2 RETURN	DS	Z5	✓		✓	✓	✓		DH100LPA
FR-2 SUPPLY	DS	Z5	✓		✓	✓	✓		D2A
MECHANICAL ROOM	EOL	Z5	✓						EOL-P1
CELLS 1-4 ZONE 6 :									
CELL 1	S	Z6	✓		✓	✓	✓	2.4%	C2W-BA.O2
CELL 2	S	Z6	✓		✓	✓	✓	2.4%	C2W-BA.O2
CELL 3	S	Z6	✓		✓	✓	✓	2.4%	C2W-BA.O2
CELL 4	S	Z6	✓		✓	✓	✓	2.4%	C2W-BA.O2
CRAWLSPACE	EOL	Z6	✓						EOL-P1
GARAGE AREA ZONE 7 :									
GARAGE	M	Z7	✓		✓	✓	✓		MIRTONE 73322
GARAGE	HT	Z7	✓		✓	✓	✓		CF135. O3
GARAGE	EOL	Z7	✓						EOL-P1

BUILDING NAME:	RCMP EMERSON DETACHMENT	
BUILDING ADDRESS:	352 DALLAS AVE. EMERSON MB.	
DATE:	MONDAY MARCH 7, 2022	
TEST NG PERFORMED BY:		

Printed Name

Signature

EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service (damaged, poor light, battery condition)	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, x=Fail	Remarks / Deficiencies / Corrective Action
BASEMENT MECHANICAL ROOM	CP	12V		160W	x					x	DUAL LITE C12AS-160-BCI BATTERIES 3-12V 12AH. D2.
BASEMENT WEIGHT ROOM	RH2										
BASEMENT	RH1										
BASEMENT	RH1										
BASEMENT	ES										
CRAWLSPACE	RH2										
TOP OF STAIRS	ES										
TOP OF STAIRS	RH2										
OFFICE AREA REAR	RH2										
OFFICE AREA REAR	ES										
OFFICE AREA FRONT	ES										
OFFICE AREA FRONT	RH2										
CELL AREA TO GARAGE	ES										
CELL AREA	RH1										
CELL AREA EXIT	ES										
CELL AREA	RH1										
CELL AREA	RH1										
BASEMENT MECHANICAL ROOM	RH1										
GARAGE	RH2										
GARAGE	ES										