



BUILDING NAME:	RCMP GODS RIVER DETACHMENT
BUILDING ADDRESS:	GODS RIVER MB.
DATE:	Friday, May 6, 2022

### C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement <small>(Sensitivity, Pressure, Time Delay, etc)</small>	Remarks / Required Additional Notes
LOCAL SMOKE ALARMS									
CELL 1	SA		✓	x	✓				D2, O1
CELL 2	SA		✓	x	✓				D2, O1
HALL BY CELLS	SA2		✓		✓				O1
GENERAL OFFICE AREA	SA2		✓	x	✓				D1, O1

RCMP GODS RIVER DETACHMENT	
BUILDING ADDRESS:	GODS RIVER MB.
DATE:	Friday, May 6, 2022
TESTING PERFORMED BY:	

Printed Name

Signature

**EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD**

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service damaged, no light, battery condition	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, ✗=Fail	Remarks / Deficiencies / Corrective Action
GENERAL OFFICE AREA	2BP	6V		36W	✓	✗	✓		30	✗	D3, LUMACELL RG442MT9W. BATTERY 1-6V7.2AH.
CELL AREA HALL	2BP	6V		36W		✓	✓		30	✓	LUMACELL RG442MT9W. BATTERY 1-6V7.2AH.