

C3 FIELD DEVICE RECORD

(Reference: Clause 6.1.6)

C6.1 FIELD DEVICE TESTING - LEGEND & NOTES

(Reference: Clauses 6.7.4.1.3, 6.7.4.1.4, 6.7.4.1.5, 6.7.4.3.1, 6.7.4.5.1, 6.7.8.1.1, 6.7.8.2.2, 6.7.8.2.4)

DEVICE	DESCRIPTION	MANUFACTURER	MODEL NO.
M	Manual Station	EST	SIGA-270P
M2	Manual Station	EST	SIGA-278
M3	Manual Station		
RHT	Rate of Rise Heat Detector	EST	SIGA-HRS
RHT2	Rate of Rise Heat Detector		
RHT3	Rate of Rise Heat Detector		
HT	Fixed Temperature Heat Detector		
HT2	Fixed Temperature Heat Detector		
HT3	Fixed Temperature Heat Detector		
S	Smoke Detector	EST	SIGA-PS
	Sensitivity Test Method:		
	Sensitivity Range:		
S2	Smoke Detector	EST	SIGA-PHD
	Sensitivity Test Method:		
	Sensitivity Range:		
S3	Smoke Detector	EST	SIGA-OSD
	Sensitivity Test Method:		
	Sensitivity Range:		
RI	Remote Indicator		
DS	Duct Smoke Detector		
SFD	Supporting Field Device - Monitor	EST	SIGA-CT2
SFD2	Supporting Field Device - Monitor		
FD	Sprinkler Flow Switch		
SS	Sprinkler Supervisory Device		
PS	Sprinkler Pressure Device		
IM	Isolation Module		
B	Bell	EST	MB10-24
B2	Bell		
H/V	Horn/Visual		
H/V2	Horn/Visual		
H	Horn		
H2	Horn		
V	Visual Signal Device	EST	G1R-VM
V2	Visual Signal Device		
SP	Cone Type Speaker		
SP2	Cone Type Speaker		
HSP	Horn Type Speaker		
AD	Ancillary Device	EST	SIGA-CR
AD2	Ancillary Device		
ET	Emergency Telephone		
EOL	End of Line Resistor/Capacitor		
EOL2	End of Line Resistor/Capacitor		

BUILDING NAME:	RCMP GODS LAKE NARROWS DETACHMENT
BUILDING ADDRESS:	GODS LAKE NARROWS MB.
DATE:	Thursday, May 5, 2022

C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
FRONT ENTRANCE VESTIBULE	FACP	EST QS1	✓		✓	✓			
DETECTION :									
ATTIC/MEZZANINE :									
ATTIC RHT	RHT	01 01 001	✓		✓	✓			
ATTIC RHT	RHT	01 01 002	✓		✓	✓			
MEZZANINE FURNACE ROOM	S	01 01 003	✓		✓	✓			
ATTIC ENTRANCE	M	01 01 131	✓		✓	✓			
ATTIC ENTRANCE	GA	01 01 132	✓		✓	✓			
ATTIC STAIRWELL	S	01 01 049	✓		✓	✓			
GARAGE :									
GARAGE BAY 1 HIGH	RHT	01 01 004	✓		✓	✓			
GARAGE BAY 1 LOW	RHT	01 01 055	✓		✓	✓			
GARAGE BAY 2 HIGH	RHT	01 01 044	✓		✓	✓			
GARAGE BAY 2 LOW	RHT	01 01 054	✓		✓	✓			
SECURE BAY EXIT	M2	01 01 130	✓		✓	✓			
CELLS & GUARDS AREA :									
CELL AREA EXIT	M	01 01 135	✓		✓	✓			
CELL AREA EXIT	GA	01 01 136	✓		✓	✓			
CELL AREA EXIT	M2	01 01 143	✓		✓	✓			
CELL 1	S	01 01 032	✓		✓	✓			O1
CELL 2	S	01 01 029	✓		✓	✓			O1
CELL 3	S	01 01 026	✓		✓	✓			O1
CELL 4	S2	01 01 039	✓		✓	✓			O1
CELL 5	S	01 01 037	✓		✓	✓			O1
CELL AREA CLOSET 01-02	RHT	01 01 017	✓		✓	✓			
CELL AREA CLOSET 03-04	RHT	01 01 006	✓		✓	✓			
CELL AREA CLOSET 05	RHT	01 01 010	✓		✓	✓			
GUARDS AREA	M2	01 01 128	✓		✓	✓			
PATROL CORRIDOR EAST	S	01 01 031	✓		✓	✓			
PATROL CORRIDOR WEST	S2	01 01 022	✓		✓	✓			
BREATHALIZER ROOM	RHT	01 01 007	✓		✓	✓			
BREATHALIZER WASHROOM	RHT	01 01 009	✓		✓	✓			
SECURE INTERVIEW ROOM	S	01 01 038	✓		✓	✓			
LAUNDRY ROOM	RHT	01 01 008	✓		✓	✓			
BACK DOOR CELL HALL	M2	01 01 129	✓		✓	✓			
MAIN OFFICE AREA :									
REAR ENTRANCE	S	01 01 035	✓		✓	✓			
REAR ENTRANCE	M	01 01 137	✓		✓	✓			
REAR ENTRANCE	GA	01 01 138	✓		✓	✓			
JANITORS ROOM	RHT	01 01 012	✓		✓	✓			

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay etc)	Remarks / Required Additional Notes
INTERVIEW ROOM	RHT	01 01 013	✓		✓	✓			
STAFF WASHROOM	RHT	01 01 046	✓		✓	✓			
SECURE EXHIBIT ROOM	S	01 01 024	✓		✓	✓			
O/N EXHIBIT ROOM	S	01 01 030	✓		✓	✓			
AREA CONTROL	S	01 01 036	✓		✓	✓			
STAFF ROOM	S	01 01 040	✓		✓	✓			
S/E GENERAL OFFICE	S	01 01 050	✓		✓	✓			
N/E GENERAL OFFICE	S	01 01 051	✓		✓	✓			
S/W GENERAL OFFICE	S3	01 01 041	✓		✓	✓			
N/W GENERAL OFFICE	S3	01 01 042	✓		✓	✓			
GUARD ROOM	S	01 01 025	✓		✓	✓			
PUBLIC WASHROOM	RHT	01 01 016	✓		✓	✓			
FILE ROOM	RHT	01 01 028	✓		✓	✓			
FRONT ENTRANCE	M	01 01 139	✓		✓	✓			
FRONT ENTRANCE	GA	01 01 140	✓		✓	✓			
GENERAL OFFICE #2	RHT	01 01 045	✓		✓	✓			
GENERAL OFFICE #3	RHT	01 01 014	✓		✓	✓			
BASEMENT :									
STORAGE AREA NORTH	RHT	01 01 005	✓		✓	✓			
STORAGE ROOM	RHT	01 01 011	✓		✓	✓			
WOMENS SHOWER ROOM	RHT	01 01 021	✓		✓	✓			
MENS SHOWER ROOM	RHT	01 01 027	✓		✓	✓			
WEIGHT ROOM SOUTH	RHT	01 01 023	✓		✓	✓			
JANITORS ROOM	RHT	01 01 033	✓		✓	✓			
BASEMENT STAIRWELL	S	01 01 034	✓		✓	✓			
COMMON AREA	S	01 01 043	✓		✓	✓			
WEIGHT ROOM NORTH	RHT	01 01 047	✓		✓	✓			
BASEMENT EXIT	M	01 01 133	✓		✓	✓			
BASEMENT EXIT	GA	01 01 134	✓		✓	✓			
CRAWLSPACES :									
CRAWLSPACE 1	RHT	01 01 015	✓		✓	✓			
CRAWLSPACE 1	RHT	01 01 018	✓		✓	✓			
CRAWLSPACE 2	RHT	01 01 052	✓		✓	✓			
CRAWLSPACE 2	RHT	01 01 053	✓		✓	✓			
BASEMENT ELECTRICAL ROOM									
NORTH	RHT	01 01 019	✓		✓	✓			
SOUTH	RHT	01 01 020	✓		✓	✓			
GENERATOR BLDG :									
CENTRE BLDG	RHT	01 01 048	✓		✓	✓			
SIGNALS :									
GARAGE BAY 1	B	NAC1	✓		✓	✓			
GARAGE BAY 2	B	NAC1	✓		✓	✓			
ATTIC MECHANICAL ROOM	B	NAC1	✓		✓	✓			
BASEMENT WEIGHT ROOM	B	NAC1	✓		✓	✓			
BASEMENT COMMON AREA	B	NAC1	✓		✓	✓			
BASEMENT ELECTRICAL ROOM	B	NAC1	✓		✓	✓			
BY CELL AREA DESK	B	NAC1	✓		✓	✓			
BY EXHIBIT ROOMS	B	NAC1	✓		✓	✓			

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
ATTIC	B	NAC1	✓		✓	✓			
GENERAL OFFICE	B	NAC1	✓		✓	✓			
BASEMENT ELECTRICAL ROOM	V	NAC2	✓		✓	✓			
ATTIC	V	NAC2	✓		✓	✓			
ATTIC MECHANICAL ROOM	V	NAC2	✓		✓	✓			
CRAWLSPACE 1	V	NAC2	✓		✓	✓			
CRAWLSPACE 2	V	NAC2	✓		✓	✓			
GENERAL OFFICE	V	NAC2	✓		✓	✓			
BASEMENT WEIGHT ROOM	V	NAC2	✓		✓	✓			
WOMENS LOCKER ROOM	V	NAC2	✓		✓	✓			
WOMENS SHOWER ROOM	V	NAC2	✓		✓	✓			
MENS LOCKER ROOM	V	NAC2	✓		✓	✓			
MENS SHOWER ROOM	V	NAC2	✓		✓	✓			
CELL AREA	V	NAC2	✓		✓	✓			
CELL AREA HALL BY CELL 5	V	NAC2	✓		✓	✓			
BY EXHIBIT ROOMS	V	NAC2	✓		✓	✓			
RELAYS :									
AHU SHUTDOWN 1	AD	01 01 126	✓		✓	✓			
AHU SHUTDOWN 2	AD	01 01 127	✓		✓	✓			
ANCILLARY CONTACT :									
GENERATOR	SFD	01 01 141	✓						
GENERATOR	SFD	01 01 142	✓						

EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service damaged, poor light, battery condition	Operation Confirmed	Heads properly aligned	Exit direction Indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, x=Fail	Remarks / Deficiencies / Corrective Action