

## C6 FIELD DEVICE RECORD

(Reference: Clause 4.2.7 and Section 6)

### C6.1 FIELD DEVICE TESTING - LEGEND & NOTES

(Reference: Clauses 6.4.1.3, 6.4.1.4, 6.4.1.5, 6.4.5.1-B, 6.8.1.1-B, 6.8.2.2-B, 6.8.2.4, Appendix C6.2, C6.3 and C6.4)

DEVICE	DESCRIPTION	MANUFACTURER	MODEL NO.
M	Manual Station	EDWARDS	270-SPOW
M2	Manual Station		
M3	Manual Station		
RHT	Rate of Rise Heat Detector		
RHT2	Rate of Rise Heat Detector		
RHT3	Rate of Rise Heat Detector		
HT	Fixed Temperature Heat Detector		
HT2	Fixed Temperature Heat Detector		
HT3	Fixed Temperature Heat Detector		
S	Smoke Detector	EDWARDS	EDW2151A
	Sensitivity Test Method:		
	Sensitivity Range:		
S2	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
S3	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
RI	Remote Indicator		
DS	Duct Smoke Detector		
SFD	Supporting Field Device - Monitor		
SFD2	Supporting Field Device - Monitor		
FD	Sprinkler Flow Switch		
SS	Sprinkler Supervisory Device		
PS	Sprinkler Pressure Device		
IM	Isolation Module		
B	Bell		
B2	Bell		
H/V	Horn/Visual	EDWARDS	G1AVRN
H/V2	Horn/Visual		
H	Horn		
H2	Horn		
V	Visual Signal Device		
V2	Visual Signal Device		
SP	Cone Type Speaker		
SP2	Cone Type Speaker		
HSP	Horn Type Speaker		
AD	Ancillary Device		
AD2	Ancillary Device		
ET	Emergency Telephone		
EOL	End of Line Resistor/Capacitor		
EOL2	End of Line Resistor/Capacitor		

BUILDING NAME:	RCMP Whitemouth
BUILDING ADDRESS:	87 Henderson ave, Whitemouth, MB
DATE:	Wednesday, May 11, 2022

### C6.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.12.1, 6.12.2 and Appendix C6.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed (If applicable)	Requires Service, Repairs, Cleaning or is Missing	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Supervision of Device Wiring Confirmed	Remarks / Required Additional Notes
<b>PANEL:</b>										
GENERAL OFFICE N/E BY CELL AREA	FAP	NODE 1	✓		✓	✓	✓		✓	
<b>DETECTORS:</b>										
GENERAL AREA N/E	S	1	✓		✓		✓		✓	
CELL AREA HALLWAY	S	1	✓		✓		✓		✓	
CELL 1	S	1	✓		✓		✓		✓	
CELL 2	S	1	✓		✓		✓		✓	
INSIDE FACP	EOL	1	✓						✓	
GENERAL AREA N/E BY F/A PANEL	M	2	✓		✓		✓		✓	N2
INSIDE PULL STATION	EOL	2	✓						✓	
<b>SIGNALLING:</b>										
GENERAL AREA N/E BY F/A PANEL	H/V	NAC 1	✓			✓	✓		✓	
INSIDE HORN STROBE	EOL	NAC 1	✓						✓	