



BUILDING NAME:	RCMP GRAND RAPIDS DETACHMENT
BUILDING ADDRESS:	24 LAKEVIEW DRIVE GRAND RAPIDS MB.
DATE:	WEDNESDAY FEB. 23,2022

### C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
FRONT MAIN ENTRANCE	FACP	MIRCOM FA-1008KA	✓		✓	✓	✓		
CELL AREA GUARDS ROOM	ANN	EDWARDS	✓		✓	✓	✓		
DEVICES :									
ZONE 1 ADMIN. AREA :									
BY MAIN ENTRANCE	M	Z1	✓		✓	✓	✓		
GENERAL OFFICE	HT	Z1	✓		✓	✓	✓		O2
STENO OFFICE	HT	Z1	✓		✓	✓	✓		O2
NCO OFFICE	HT	Z1	✓		✓	✓	✓		O2
FILE ROOM	HT	Z1	✓		✓	✓	✓		O2
LUNCH ROOM	HT	Z1	✓		✓	✓	✓		O2
SOFT INTERVIEW ROOM	HT	Z1	✓		✓	✓	✓		O2
JANITORS CLOSET	RHT	Z1	✓		✓	✓	✓		
REAR STAIRS	M	Z1	✓		✓	✓	✓		
REAR STAIRS	S	Z1	✓	x	✓	✓	✓		D1,O1
STORAGE ROOM	HT	Z1	✓		✓	✓	✓		O2
CELLAREA ZONE 2:									
BREATHALIZER ROOM	S	Z2	✓	x	✓	✓	✓		D1
GUARDS STATION	S	Z2	✓	x	✓	✓	✓		D1
GUARDS STATION	M	Z2	✓		✓	✓	✓		
INNER EXHIBIT ROOM	S	Z2	✓	x	✓	✓	✓		D1
OUTER EXHIBIT ROOM	S	Z2	✓	x	✓	✓	✓		D1
CELL HALL EAST	S	Z2	✓	x	✓	✓	✓		D1
CELL HALL WEST	S	Z2	✓	x	✓	✓	✓		D1
GARAGE	M	Z2	✓		✓	✓	✓		
GARAGE	HT	Z2	✓		✓	✓	✓		O2
PIPECHASE CABINET BETWEEN CELLS 1-2	HT	Z2	✓		✓	✓	✓		O2
PIPECHASE CABINET BETWEEN CELLS 3-4	HT	Z2	✓		✓	✓	✓		O2
BASEMENT ZONE 3:									
BY STAIRS	M	Z3	✓		✓	✓	✓		
MECHANICAL ROOM ENTRANCE	HT	Z3	✓		✓	✓	✓		O2
MECHANICAL ROOM BACK	HT	Z3	✓		✓	✓	✓		O2
GYM SOUTH	HT	Z3	✓		✓	✓	✓		O2
GYM N/E	HT	Z3	✓		✓	✓	✓		O2
GYM NORTH	HT	Z3	✓		✓	✓	✓		O2
CRAWLSPACE ZONE 4:									
EAST	HT	Z4	✓		✓	✓	✓		O2
CENTRE	HT	Z4	✓		✓	✓	✓		O2
WEST	HT	Z4	✓		✓	✓	✓		O2

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
DUCT SMOKES ZONE 5:									
MECHANICAL ROOM FR1 SUPPLY	DS	Z5	✓		✓	✓	✓		
MECHANICAL ROOM FR1 RETURN	DS	Z5	✓		✓	✓	✓		
MECHANICAL ROOM FR2 SUPPLY	DS	Z5	✓		✓	✓	✓		
CRAWLSPACE FR2 RETURN	DS	Z5	✓		✓	✓	✓		
CELLS ZONE 6:									
CELL 1	S	Z6	✓	x	✓	✓	✓		D1,03
CELL 2	S	Z6	✓	x	✓	✓	✓		D1,03
CELL 3	S	Z6	✓	x	✓	✓	✓		D1,03
CELL 4	S	Z6	✓	x	✓	✓	✓		D1,03
SIGNALS NAC1:									
BASEMENT MECHANICAL ROOM	B	NAC1	✓		✓				
BASEMENT GYM	B	NAC1	✓		✓				
GENERAL OFFICE	B	NAC1	✓		✓				
CELL AREA	B	NAC1	✓		✓				

BUILDING NAME:	RCMP GRAND RAPIDS DETACHMENT	
BUILDING ADDRESS:	24 LAKEVIEW DRIVE GRAND RAPIDS MB.	
DATE:	WEDNESDAY FEB. 23, 2022	
TEST NG PERFORMED BY:		

Printed Name

Signature

### EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service (damaged, poor light, battery condition)	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, x=Fail	Remarks / Deficiencies / Corrective Action
BASEMENT MECHANICAL ROOM	2BP	12V		360W		✓	✓		30	✓	O4. AIM-LITE EBST12360. BATTERY 1-12V 35AH.
WEIGHT ROOM BASEMENT	RH2					✓	✓			✓	
BASEMENT LOCKER ROOM WEST	RH1					✓	✓			✓	
BASEMENT LOCKER ROOM EAST	RH1					✓	✓			✓	
CRAWLSPACE EAST	RH2				x	✓	✓			x	D3. 12V 9W BULB OR DOUBLE REMOTE HEAD.
BASEMENT LOCKER ROOM EXIT TO STAIRS	ES					✓		✓		✓	
MAIN FLOOR TOP OF STAIR EXIT	ES					✓		✓		✓	
MAIN FLOOR TOP OF STAIR EXIT	RH2					✓	✓			✓	
GENERAL OFFICE EXIT TO STAIRS	ES					✓		✓		✓	
GENERAL OFFICE S/W	RH1					✓	✓			✓	
GENERAL OFFICE N/W	RH1					✓	✓			✓	
STENO OFFICE	RH1					✓	✓			✓	
GENERAL OFFICE ENTRANCE	ES					✓		✓		✓	
GARAGE SOUTH WALL	RH2					✓	✓			✓	
GARAGE	ES					✓		✓		✓	
CELL HALL EAST	RH1					✓	✓			✓	
GUARDS DESK	RH1					✓	✓			✓	
CELL AREA HALL WEST EXIT	RH1					✓	✓			✓	
CELL AREA HALL WEST EXIT	ES					✓		✓		✓	