

BUILDING NAME:	RCMP MOOSE LAKE DETACHMENT
BUILDING ADDRESS:	28 SPRUCE ST. MOOSE LAKE MB.
DATE:	WEDNESDAY MARCH 30,2022

C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
FRONT ENTRANCE VESTIBULE	FACP	EST IO500	✓		✓	✓	✓		
CELL DESK	ANN	EST	✓		✓	✓	✓		
DEVICES :									
REAR INTERVIEW ROOM	S	1	✓		✓	✓	✓		
IN CEILING IN CENT	IM	2	✓		✓	✓	✓		
ELECTRICAL ROOM	S	3	✓		✓	✓	✓		
OUTER EXHIBIT LOCKER	S	4	✓		✓	✓	✓		
COFFEE ROOM	S	5	✓		✓	✓	✓		
NORTH HALL CENTRE	S	6	✓		✓	✓	✓		
CENTRE CORRIDOR NORTH	S	7	✓		✓	✓	✓		
PUBLIC WASHROOM	S	8	✓		✓	✓	✓		
TELEPHONE ROOM	S	9	✓		✓	✓	✓		
FRONT INTERVIEW ROOM	S	10	✓		✓	✓	✓		
DATA ROOM	S	11	✓		✓	✓	✓		
BRFEATHALIZER ROOM	S	12	✓		✓	✓	✓		
EXERCISE ROOM	S	13	✓		✓	✓	✓		
NORTH HALL EAST	S	14	✓		✓	✓	✓		
MEZZANINE CENTRE	RHT	15	✓		✓	✓	✓		
NORTH HALL WEST	S	16	✓		✓	✓	✓		
LAUNDRY ROOM	S	17	✓		✓	✓	✓		
GENERAL STORAGE ROOM	RHT	18	✓		✓	✓	✓		
WOMENS WASHROOM	RHT	19	✓		✓	✓	✓		
KITCHEN	S	20	✓		✓	✓	✓		
WEST CELL AREA MECHANICAL ROOM	RHT	21	✓		✓	✓	✓		
CELL AREA WASHROOM	S	22	✓		✓	✓	✓		
SECURE BAY / GARAGE	RHT	23	✓		✓	✓	✓		
JANITORS ROOM	S	24	✓		✓	✓	✓		
BASEMENT SOUTH	RHT	25	✓		✓	✓	✓		
BASEMENT NORTH	RHT	26	✓		✓	✓	✓		
PRISONER EFFECTS ROOM	S	27	✓		✓	✓	✓		
MENS WASHROOM	RHT	28	✓		✓	✓	✓		
CELL 4	S	29	✓		✓	✓	✓		
CELL 3	S1	30	✓		✓	✓	✓		
IN MEZZANINE ABOVE CELL 1	IM	31	✓		✓	✓	✓		
IN MEZZANINE ABOVE CELL 2	IM	32	✓		✓	✓	✓		
IN MEZZANINE ABOVE CELL 4	IM	33	✓		✓	✓	✓		
CELL 2	S1	34	✓		✓	✓	✓		
CENTRE HALL ABOVE	IM	35	✓		✓	✓	✓		
AHU 2 DUCT SMOKE	DS	36	✓		✓	✓	✓		
TOP OF STAIRS MEZZANINE	S	37	✓		✓	✓	✓		
AHU 1 DUCT SMOKE	DS	38	✓		✓	✓	✓		

BUILDING NAME:	RCMP MOOSE LAKE DETACHMENT	
BUILDING ADDRESS:	28 SPRUCE ST. MOOSE LAKE MB.	
DATE:	WEDNESDAY MARCH 30,2022	
TEST NG PERFORMED BY:		

Printed Name

Signature

EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service (damaged, poor light, battery condition)	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, ✗ = Fail	Remarks / Deficiencies / Corrective Action
INNER EXH BIT ROOM	2BP	12V		360W	x					x	D1. EMERGI-LITE MR-16. BATTERY 1-12V 35AH.
TELEPHONE ROOM	2BP	12V		360W	x					x	D1. EMERGI-LITE MR-16. BATTERY 1-12V 35AH.
EXTERIOR ELECTRICAL ROOM	2BP	12V		360W	x					x	D1. EMERGI-LITE MR-16. BATTERY 1-12V 35AH.
MEZZANINE	2BP	12V		360W	x					x	D1. EMERGI-LITE MR-16. BATTERY 1-12V 35AH.
GARAGE	2BP	12V		360W	x					x	D1. EMERGI-LITE MR-16. BATTERY 1-12V 35AH.
IT ROOM	2BP	12		360W	x					x	D1. EMERGI-LITE MR-16. BATTERY 1-12V 35AH.
OFFICE	2BP	12V		360W	x					x	D1. EMERGI-LITE MR-16. BATTERY 1-12V 35AH.