

### C3 FIELD DEVICE RECORD

(Reference: Clause 6.1 6)

#### C6.1 FIELD DEVICE TESTING - LEGEND & NOTES

(Reference: Clauses 6.7.4.1.3, 6.7.4.1.4, 6.7.4.1.5, 6.7.4.3.1, 6.7.4.5.1, 6.7.8.1.1, 6.7.8.2.2, 6.7.8.2.4)

DEVICE	DESCRIPTION	MANUFACTURER	MODEL NO.
M	Manual Station	MIRCOM	MS-401AD
M2	Manual Station		
M3	Manual Station		
RHT	Rate of Rise Heat Detector	MIRCOM	
RHT2	Rate of Rise Heat Detector		5601A
RHT3	Rate of Rise Heat Detector		CR135
HT	Fixed Temperature Heat Detector		CF135
HT2	Fixed Temperature Heat Detector		
HT3	Fixed Temperature Heat Detector		
S	Smoke Detector	SYSTEM SENSOR	C2W-BA
	Sensitivity Test Method:		
	Sensitivity Range:		
S2	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
S3	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
RI	Remote Indicator		
DS	Duct Smoke Detector		
SFD	Supporting Field Device - Monitor		
SFD2	Supporting Field Device - Monitor		
FD	Sprinkler Flow Switch		
SS	Sprinkler Supervisory Device		
PS	Sprinkler Pressure Device		
IM	Isolation Module		
B	Bell		
B2	Bell		
H/V	Horn/Visual	MIRCOM	
H/V2	Horn/Visual		
H	Horn	MIRCOM	
H2	Horn		
V	Visual Signal Device		
V2	Visual Signal Device		
SP	Cone Type Speaker		
SP2	Cone Type Speaker		
HSP	Horn Type Speaker		
AD	Ancillary Device		
AD2	Ancillary Device		
ET	Emergency Telephone		
EOL	End of Line Resistor/Capacitor		EOL-P1
EOL2	End of Line Resistor/Capacitor		

BUILDING NAME:	RCMP WINNIPEG VEHICLE GARAGE
BUILDING ADDRESS:	1560 SEEL AVE. WPG. MB.
DATE:	FRIDAY APRIL 8,2022

### C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
NORTH OFFICE N/W ENTRANCE	FACP	MIRCOM FX-2000	✓		✓	✓	✓		
SOUTH GARAGE WEST ENTRANCE	ANN	MIRCOM RA-1000	✓		✓	✓	✓		
DEVICES :									
NORTH BAY BELOW SOUTH MEZZ	S	02 016							O2
NORTH BAY BELOW SOUTH MEZZ	RHT	02 017							O2
NORTH OFFICE WEST ENTRANCE	M	02 102	✓		✓		✓		
NORTH OFFICE LAUNDRY ROOM	RHT	02 002	✓		✓		✓		
NORTH OFFICE ELECTRICAL ROOM	RHT	02 001	✓		✓		✓		
NORTH OFFICE NORTH EXIT	M	02 103	✓		✓		✓		
NORTH OFFICE LAN ROOM	S	02 006	✓		✓		✓	2.4%	
NORTH OFFICE LAN ROOM	RHT	02 005	✓		✓		✓		
SOUTH BAY LAN ROOM	RHT	03 008	✓		✓		✓		
NORTH OFFICE TRAINING BRANCH ROOM 5	RHT	02 004	✓		✓		✓		
EMERGENCY RESPONSE TEAM LOCKER ROOM	RHT	02 008	✓		✓		✓		
NORTH GARAGE N/E EXIT	M	02 106	✓		✓		✓		
NORTH GARAGE S/E EXIT	M	02 110	✓		✓		✓		
SOUTH GARAGE N/E EXIT	M	02 111	✓		✓		✓		
SOUTH GARAGE SOUTH EXIT	M	02 112	✓		✓		✓		
SOUTH GARAGE S/W EXIT	M	02 113	✓		✓		✓		
SOUTH GARAGE SMALL PARTS ROOM	RHT	02 019	✓		✓		✓		
SOUTH GARAGE EQUIPMENT ROOM	RHT	02 020	✓		✓		✓		
SOUTH GARAGE STORAGE ROOM	RHT	02 021	✓		✓		✓		
SOUTH GARAGE 2ND LEVEL LAN ROOM	S	03 007	✓		✓		✓	2.4%	
SOUTH GARAGE 2ND LEVEL OFFICE SUPPLY ROOM	RHT	03 006	✓		✓		✓		
NORTH GARAGE GUN SERVICE ROOM	RHT	02 016	✓		✓		✓		
NORTH GARAGE GUN CLEANING ROOM	RHT	02 017	✓		✓		✓		
SPECIAL I OFFICE	HT	03 003	✓		✓		✓		O1
NORTH GARAGE WEST EXIT	M	02 108	✓		✓		✓		
NORTH GARAGE N/W EXIT	M	02 107	✓		✓		✓		
NORTH OFFICE GUN STORAGE	HT	02 009							O2
NORTH OFFICE GUN CLEANING	HT	02 010							O2
NORTH BAY BELOW SOUTH MEZZ WEST ROOM	RHT	02 015	✓		✓		✓		
EMERGENCY RESPONSE TEAM	HT	02 012	✓		✓		✓		
NORTH BAY BOMB WORKSHOP	HT	02 011	✓		✓		✓		
NORTH WORKSHOP	RHT	02 013	✓		✓		✓		
SOUTH GARAGE AREA :									
SOUTH RUN :									
WEST	RHT	01 007	✓		✓		✓		O1
CENTRE WEST	RHT	01 007	✓		✓		✓		O1
OVER WATER TANK ON MEZZANINE	RHT	01 007	✓		✓		✓		O1

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
CENTRE	HT	01 007	✓		✓		✓		O1
CENTRE EAST	RHT	01 007	✓		✓		✓		O1
EAST	RHT	01 007	✓		✓		✓		O1
EAST	EOL	01 007	✓						O1
CENTRE RUN :									
EAST	EOL	01 006	✓						O1
EAST	RHT	01 006	✓		✓		✓		O1
CENTRE	HT	01 006	✓		✓		✓		O1
WEST	HT	01 006	✓		✓		✓		O1
NORTH RUN :									
WEST	RHT	01 005	✓		✓		✓		O1
CENTRE WEST	RHT	01 005	✓		✓		✓		O1
CENTRE	RHT	01 005	✓		✓		✓		O1
CENTRE EAST	RHT	01 005	✓		✓		✓		O1
EAST	RHT	01 005	✓		✓		✓		O1
EAST	EOL	01 005	✓						O1
NORTH GARAGE AREA :									
NORTH RUN :									
WEST	RHT	01 000	✓		✓		✓		O1
CENTRE WEST	RHT	01 000	✓		✓		✓		O1
CENTRE	RHT	01 000	✓		✓		✓		O1
CENTRE EAST	RHT	01 000	✓		✓		✓		O1
EAST	RHT	01 000	✓		✓		✓		O1
EAST	EOL	01 000	✓						O1
CENTRE RUN NORTH:									
WEST	RHT	01 001	✓		✓		✓		O1
CENTRE WEST	RHT	01 001	✓		✓		✓		O1
CENTRE	RHT	01 001	✓		✓		✓		O1
CENTRE EAST	RHT	01 001	✓		✓		✓		O1
EAST	RHT	01 001	✓		✓		✓		O1
EAST	EOL	01 001	✓						O1
CENTRE RUN:									
WEST	RHT	01 002	✓		✓		✓		O1
CENTRE WEST	RHT	01 002	✓		✓		✓		O1
CENTRE	RHT	01 002	✓		✓		✓		O1
CENTRE EAST	RHT	01 002	✓		✓		✓		O1
EAST	RHT	01 002	✓		✓		✓		O1
EAST	EOL	01 002	✓						O1
CENTRE RUN SOUTH :									
EAST	HT	01 003	✓		✓		✓		O1
EAST	EOL	01 003							O1
EAST	RHT	01 003	✓		✓		✓		O1
CENTRE EAST	RHT	01 003	✓		✓		✓		O1
CENTRE	RHT	01 003	✓		✓		✓		O1
CENTRE WEST	RHT	01 003	✓		✓		✓		O1
WEST	RHT	01 003	✓		✓		✓		O1
SOUTH RUN :									
EAST	EOL	01 004	✓						O2
EAST	RHT	01 004	✓						O2
CENTRE EAST	RHT	01 004	✓						O2

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
CENTRE	HT	01 004	✓						O2
WEST	RHT	01 004	✓						O2
SIGNALS :									
NORTH OFFICE HALL BY EMERGENCY RESPONSE TEAM	HV		✓		✓				
NORTH OFFICE GENERAL OFFICE	HV		✓		✓				
NORTH OFFICE HALL BY LUNCH ROOM	HV		✓		✓				
NORTH OFFICE HALL BY OC CRISIS ROOM	HV		✓		✓				
NORTH OFFICE TRAINING BRANCH ROOM	HV		✓		✓				
NORTH GARAGE N/E	HV		✓		✓				
NORTH GARAGE NORTH WALL	HV		✓		✓				
NORTH GARAGE N/W	HV		✓		✓				
NORTH GARAGE S/W	HV		✓		✓				
NORTH GARAGE S/E	HV		✓		✓				
SOUTH GARAGE S/E	HV		✓		✓				
SOUTH GARAGE N/W	HV		✓		✓				
SOUTH GARAGE STORAGE ROOM	V		✓		✓				
SOUTH GARAGE 2ND LEVEL LUNCH ROOM	HV		✓		✓				
SOUTH GARAGE 2ND LEVEL LAN ROOM	V		✓		✓				
SOUTH GARAGE 2ND LEVEL OFFICE	V		✓		✓				
SOUTH OFFICE AREA HALL BY WASHROOMS	HV		✓		✓				
SOUTH GARAGE OFFICE MAIN LEVEL	V		✓		✓				

BUILDING NAME:	RCMP WINNIPEG VEHICLE GARAGE	
BUILDING ADDRESS:	1560 SEEL AVE. WPG. MB.	
DATE:	FRIDAY APRIL 8, 2022	
TEST NG PERFORMED BY:		

Printed Name

Signature

### EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service damaged, poor light, battery condition	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, x=Fail	Remarks / Deficiencies / Corrective Action
SOUTH GARAGE :											
S/W EXIT BY ANNUNCIATOR	CP	12V		50W		✓	✓	✓	30	x	O3. EMERGI-LITE ESC1250W2MA. BATTERY 1-12V 5AH.
STORAGE ROOM NORTH WALL	CP	12V		216W		✓	✓	✓	30	✓	EMERGI-LITE 12ESL216-2MA. BATTERIES 4-6V 12AH.
S/E EXIT	CP	12V		50W		✓	✓	✓	30	✓	O3. EMERGI-LITE ESC1250W2MA. BATTERIES 2-6V 5AH.
N/E EXIT	CP	12V		50W		✓	✓	✓	30	✓	O3. EMERGI-LITE ESC1250W2MA. BATTERIES 2-6V 5AH.
N/E GARAGE ON POLE	CP	12V		216W		✓	✓	✓	30	✓	EMERGI-LITE 12ESL216-2MA. BATTER ES 2-12V 12AH.
2ND LEVEL LAN ROOM	CP	6V		36W		✓	✓	✓	30	✓	LUMACELL RGC442MT9W. BATTERY 1-6V 7.2AH.
NW WALL	CP	12V		216W		✓	✓	✓	30	✓	EMERGI-LITE 12ESL216-2MA. BATTER ES 2-12V 12AH.
NORTH GARAGE :											
S/E EXIT	CP	12V		50W		✓	✓	✓	30	✓	O3. EMERGI-LITE ESC1250W2MA. BATTERIES 2-6V 5AH.
UNDERWATER RECOVERY TEAM ROOM	CP	12V		216W		✓	✓	✓	30	✓	EMERGI-LITE 12ESL250W2MA. BATTER ES 4-6V 12AH.
WEST EXIT	CP	12V		50W		✓	✓	✓	30	✓	EMERGI-LITE ESC1250W2MA. BATTER ES 1-12V 5AH.
SOUTH CENTRE POLE	CP	12V		216W		✓	✓	✓	30	✓	EMERGI-LITE 12ESL216-2MA. BATTER ES 2-12V 12AH.
NW EXIT	CP	12V		50W		✓	✓	✓	30	✓	O3. EMERGI-LITE ESC1250W2MA. BATTERIES 1-12V 5AH.
N/E EXIT	CP	12V		50W		✓	✓	✓	30	✓	EMERGI-LITE ESC1250W2MA. BATTER ES 1-12V 5AH.
NORTH CENTRE POLE	CP	12V		216W		✓	✓	✓	30	✓	EMERGI-LITE 12ESL250W2MA. BATTER ES 2-12V 12AH.
NORTH OFFICE AREA :											
WEST OFFICE EMERGENCY RESPONSE TEAM	CP	12V		216W		✓	✓	✓	30	✓	EMERGI-LITE 12ESL216-2MA. BATTERY 1-12V 35AH.
NORTH OFFICE LAN ROOM	CP	12V		216W		✓	✓	✓	30	✓	EMERGI-LITE 12ESL216-2MA. BATTERY 1-12V 35AH.
NORTH OFFICE LAN ROOM	CP	12V		216W		✓	✓	✓	30	✓	EMERGI-LITE 12ESL216-2MA. BATTERY 1-12V 35AH.