

BUILDING NAME:	Dauphin RCMP
BUILDING ADDRESS:	2 Hedderley St, Dauphin MB, R7N 3M2
DATE:	MARCH 24-25,2022

C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
Detection									
RECEPTION AREA	S	1030002	✓		✓		✓	3.5%	
HALL BY BREATHALYZER	S	1030003	✓		✓		✓	3.5%	
BREATHALYZER ROOM	S	1030004	✓		✓		✓	3.5%	
CELL # 7	S	1030005	✓		✓		✓	3.5%	
CELL # 8	S	1030006	✓		✓		✓	3.5%	
CELL # 9	S	1030007	✓		✓		✓	3.5%	
CELL # 10	S	1030008	✓		✓		✓	3.5%	
CELL # 11	S	1030009	✓		✓		✓	3.5%	
HALL BY CELL 10	S	1030010	✓		✓		✓	3.5%	
CORRIDOR 137	S	1030011	✓		✓		✓	3.5%	
GUARDS WASHROOM	S1	1030012	✓		✓		✓	3.5%	
CELL SIDE PHONE ROOM	S1	1030013	✓		✓		✓	3.5%	
ROOM 138 GUARD DESK	S1	1030014	✓		✓		✓	3.5%	
ROOM 146 INTERVIEW ROOM	S1	1030015	✓		✓		✓	3.5%	
CORRIDOR 103	S1	1030016	✓		✓		✓	3.5%	
RM 135 O/N EXHIBIT	RHT	1030017	✓		✓		✓		
RM 134 SECURE EXHIBIT	RHT	1030018	✓		✓		✓		DISPLAYS AS SECURE EXIT / PROGRAM CHANGE REQUIRED. R1
VISITOR SIDE PHONE ROOM	RHT	1030019	✓		✓		✓		
CELL # 11 PIPE CHASE	RHT	1030020	✓		✓		✓		
ROOM 152 PARADE ROOM	RHT	1030021	✓		✓		✓		
ROOM 154 PUBLIC WASHROOM	RHT	1030022	✓		✓		✓		
MAIN WORK STATION	RHT	1030023	✓		✓		✓		
NORTH GENERAL OFFICE	RHT	1030024	✓		✓		✓		
104 INTERVIEW ROOM	RHT	1030025	✓		✓		✓		
ELEVATOR LOBBY	RHT	1030026	✓		✓		✓		
DETECTIVE COMMAND	RHT	1030027	✓		✓		✓		
OPS / NCO	RHT	1030028	✓		✓		✓		
SOUTH GENERAL OFFICE	RHT	1030029	✓		✓		✓		
HP / NCO	RHT	1030030	✓		✓		✓		
PSD NCO /IC	RHT	1030031	✓		✓		✓		
TELEPHONE ROOM	RHT	1030032	✓		✓		✓		
CONTAINMENT STORAGE	RHT	1030033	✓		✓		✓		
ROOM 119 MALE WASHROOM	RHT	1030034	✓		✓		✓		
ROOM 119 FEMALE WASHROOM	RHT	1030035	✓		✓		✓		
EAST WASHROOM CORRIDOR	RHT	1030036	✓		✓		✓		
ROOM 124 JANITOR	RHT	1030037	✓		✓		✓		
EAST GARAGE 123	RHT	1030038	✓		✓		✓		
EAST END CORRIDOR	RHT	1030039	✓		✓		✓		
GARAGE CORRIDOR	RHT	1030040	✓		✓		✓		
TRAFFIC OFFICE	RHT	1030041	✓		✓		✓		
ROOM 114 SHIFT OFFICE	RHT	1030042	✓		✓		✓		
ROOM 113 FILE RECORDS	RHT	1030043	✓		✓		✓		
ROOM 131 GARAGE STORAGE	RHT	1030044	✓		✓		✓		
SECURE BAY ROOM 133	RHT	1030045	✓		✓		✓		
GARAGE CORRIDOR	RHT	1030046	✓		✓		✓		
CELL # 8 PIPE CHASE	HT	1030047	✓		✓		✓		PROGRAM CHANGE REQUIRED TO CLEANING SUPPLY CLOSET. R1
CAR EXAMINATION	HT	1030048	✓		✓		✓		
CENTRE GARAGE	HT	1030049	✓		✓		✓		
VEHICLE WORK AREA	HT	1030050	✓		✓		✓		
MAINT. STORAGE	HT	1030051	✓		✓		✓		
FRONT ENTRANCE	M	1030131	✓		✓		✓		
HALL BY CELL #11	M	1030132	✓		✓		✓		
HALL BY GARAGE	M	1030133	✓		✓		✓		
SECURE BAY	M	1030134	✓		✓		✓		
VEHICLE WORK AREA	M	1030135	✓		✓		✓		
ELEVATOR LOBBY	M	1030136	✓		✓		✓		
STAIR #2 EAST	M	1030137	✓		✓		✓		

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
STAIR #1 WEST	M	1030138	✓		✓		✓		
EAST VESTIBULE	M	1030139	✓		✓		✓		
CRAWLSPACE EAST	RHT	1030251	✓		✓		✓		
CRAWLSPACE	RHT	1030252	✓		✓		✓		
CRAWLSPACE	RHT	1030253	✓		✓		✓		
CRAWLSPACE	RHT	1030254	✓		✓		✓		
CRAWLSPACE WEST	RHT	1030255	✓		✓		✓		
RANGE OBSERVATION	RHT	1030256	✓		✓		✓		
MUNITION STORAGE	RHT	1030257	✓		✓		✓		
WEAPONS MAINTENANCE	RHT	1030258	✓		✓		✓		
SHOOTING AREA	RHT	1030259	✓		✓		✓		
GUN RANGE ABOVE CEILING	RHT	1030260	✓		✓		✓		
GUN RANGE	RHT	1030261	✓		✓		✓		
GUN RANGE	RHT	1030262	✓		✓		✓		
GUN RANGE	RHT	1030263	✓		✓		✓		
BASEMENT WASHROOMS	RHT	1030264	✓		✓		✓		
BASEMENT ELEV VESTIBULE	RHT	1030265	✓		✓		✓		
BASEMENT HALL WEST END	RHT	1030266	✓		✓		✓		
BASEMENT ELEV MACHINE RM	RHT	1030267	✓		✓		✓		
BASEMENT PSP STORAGE	RHT	1030268	✓		✓		✓		
BASEMENT WEIGHT ROOM	RHT	1030269	✓		✓		✓		
BASEMENT WEIGHT ROOM	RHT	1030270	✓		✓		✓		
BASEMENT WEIGHT ROOM	RHT	1030271	✓		✓		✓		
BASEMENT WEIGHT ROOM	RHT	1030272	✓		✓		✓		
BASEMENT LOCKER ROOM	RHT	1030273	✓		✓		✓		
BASEMENT TELEPHONE ROOM	RHT	1030274	✓		✓		✓		
BASEMENT FEMALE LOCKERS	RHT	1030275	✓		✓		✓		
BASEMENT MALE LOCKERS	RHT	1030276	✓		✓		✓		
BASEMENT JANITORS ROOM	RHT	1030277	✓		✓		✓		
2ND FLOOR MECH RM WEST	RHT	1030278	✓		✓		✓		
2ND FLOOR MECH RM EAST	RHT	1030279	✓		✓		✓		
2ND FLOOR MECH RM NORTH	RHT	1030280	✓		✓		✓		
2ND FLOOR GENERATOR RM	RHT	1030281	✓		✓		✓		
2ND FLOOR ELECTRICAL RM	RHT	1030282	✓		✓		✓		
ATTIC AREA	RHT	1030283	✓		✓		✓		
ATTIC AREA	RHT	1030284	✓		✓		✓		
2ND FLOOR OFFICE # 1	RHT	1030285	✓		✓		✓		
2ND FLOOR MALE WASHROOM	RHT	1030286	✓		✓		✓		
2ND FLOOR FEMALE WASHROOM	RHT	1030287	✓		✓		✓		
2ND FLOOR GENERAL OFFICE	RHT	1030288	✓		✓		✓		
2ND FLOOR OFFICE # 2	RHT	1030289	✓		✓		✓		
2ND FLOOR OFFICE # 3	RHT	1030290	✓		✓		✓		
2ND FLOOR OFFICE # 4	RHT	1030291	✓		✓		✓		
2ND FLOOR GENERAL OFFICE	RHT	1030292	✓		✓		✓		
2ND FLOOR OFFICE # 5	RHT	1030293	✓		✓		✓		
2ND FLOOR HALLWAY	RHT	1030294	✓		✓		✓		
2ND FLOOR OFFICE BY MECH	RHT	1030295	✓		✓		✓		
2ND FLOOR FILE STORAGE	RHT	1030296	✓		✓		✓		
2ND FLOOR MONITOR RM	RHT	1030297	✓		✓		✓		
2ND FLOOR INTERVIEW RM	RHT	1030298	✓		✓		✓		
2ND FLOOR PROJECT RM	RHT	1030299	✓		✓		✓		
2ND FLOOR CONFERENCE ROOM	RHT	1030300	✓		✓		✓		
MAIN LOBBY	RHT	1030301	✓		✓		✓		
MAIN LOBBY	RHT	1030302	✓		✓		✓		
2ND FLOOR MECH RM CORRIDOR	RHT	1030303	✓		✓		✓		
2ND FLOOR EAST CORRIDOR	RHT	1030304	✓		✓		✓		
2ND FLOOR EXAM ROOM	RHT	1030305	✓		✓		✓		
2ND FLOOR DARK ROOM / PHOTOGRAPHY ROOM	RHT	1030306	✓		✓		✓		
2ND FLOOR STUDIO	RHT	1030307	✓		✓		✓		
2ND FLOOR OFFICE	RHT	1030308	✓		✓		✓		
CELL BLOCK EXHAUST DUCT	S1	1030309	✓		✓		✓	3.5%	CRAWLSPACE
SERVICE SHAFT DUCT	S1	1030310	✓		✓		✓	3.5%	CUBBYHOLE IN CAR EXAMINATION.
2ND FLR MECH RM R7-1 DUCT	S1	1030311	✓		✓		✓	3.5%	2ND FLR MECH ROOM
2ND FLR MECH RM AHU-2 DUCT	S1	1030312	✓		✓		✓	3.5%	2ND FLR MECH ROOM
ELEVATOR SHAFT SMOKE	S1	1030313	✓		✓				O3
WEST STAIRWELL # 1 SMOKE	S1	1030314	✓		✓		✓	3.5%	REQUIRES SCAFFOLDING IF REPLACEMENT NEEDED
EAST STAIRWELL # 2 SMOKE	S1	1030315	✓		✓		✓	3.5%	REQUIRES SCAFFOLDING IF REPLACEMENT NEEDED

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
2ND FLOOR ELEV VESTIBULE SMOKE	S	1030316	✓		✓		✓	3.5%	
2ND FLOOR MAJOR CRIMES SMOKE	S	1030317	✓		✓		✓	3.5%	
2ND FLOOR MAJOR CRIMES SMOKE	S	1030318	✓		✓		✓	3.5%	
2ND FLOOR SERVER ROOM SMOKE	S	1030319	✓		✓		✓	3.5%	
2ND FLOOR IM OFFICE SMOKE	S	1030320	✓		✓		✓	3.5%	PROGRAM CHANGE REQUIRED TO 2ND FLOOR SERVER ROOM SMOKE. R1.
BASEMENT WEST HALLWAY	M	1030402	✓		✓		✓		
BASEMENT EAST HALLWAY	M	1030403	✓		✓		✓		
2ND FLOOR WEST HALLWAY	M	1030404	✓		✓		✓		
2ND FLOOR EAST HALLWAY	M	1030405	✓		✓		✓		
2ND FLOOR MAJOR CRIMES	M	1030406	✓		✓		✓		
2ND FLOOR MECHANICAL ROOM	M	1030407	✓		✓		✓		
RELAY MODULES									
RELAY CCT #1	AD	1030126	✓		✓		✓		
RELAY CCT #2	AD	1030127	✓		✓		✓		
RELAY CCT #3	AD	1030128	✓		✓		✓		
RELAY CCT #4	AD	1030129	✓		✓		✓		
RELAY CCT #5	AD	1030130	✓		✓		✓		
MAG DOOR HOLDER RELAY	AD	1030381	✓		✓		✓		
EMCC MOTOR SHUTDOWN RELAY	AD	1030382	✓		✓		✓		
MCC MOTOR SHUTDOWN RELAY	AD	1030383	✓		✓		✓		
VACUUM CLEANER SHUTDOWN RELAY	AD	1030384	✓		✓		✓		
SPRINKLER PRE-ACTION SOLENOID RELAY	AD	1030385							O1
SPRINKLER MODULES									
CRAWL SPACE MAIN WATER VALVE TAMPER	SFD1	1030376							O1
MAIN SPRINKLER TAMPER VALVE	SFD1	1030377							O1
P-10 PUMP POWER OFF	SFD1	1030378							O1
GENSET COMMON FAULT	SFD1	1030379							O1
SEWER/SUMP PITS HIGH WATER ALERT	SFD1	1030380							O1
BASEMENT SPRINKLER TAMPER VALVE	SFD2	1030394							O1
BASEMENT SPRINKLER WATER FLOW	SFD2	1030395							O1
CELL SPRINKLER TAMPER VALVE	SFD2	1030396							O1
CELL SPRINKLER WATER FLOW	SFD2	1030397							O1
SPRINKLER SYSTEM LOW PRESSURE	SFD2	1030398							O1
MAIN SPRINKLER WATER FLOW	SFD2	1030399							O1
SPRINKLER PRE-ACTION WATER FLOW	SFD2	1030400							O1
SPRINKLER PRE-ACTION LOW PRESSURE	SFD1	1030408							O1
SPRINKLER PRE-ACTION TAMPER VALVE	SFD2	1030409							O1
AUDIBLE / VISUAL MODULES									
NAC CCT FOR CC1 RISER MODULES		1020004	✓			✓			
BELL CIRCUIT #4		1030141	✓			✓			
2ND FLOOR BELL CCT #5		1030386	✓			✓			
2ND FLOOR BELL CCT #6		1030387	✓			✓			
2ND FLOOR STROBE CCT #5		1030388	✓			✓			
2ND FLOOR STROBE CCT #6		1030389	✓			✓			
BASEMENT BELL CCT #1		1030390	✓			✓			
BASEMENT BELL CCT #2		1030391	✓			✓			
BASEMENT STROBE CCT #1		1030392	✓			✓			
BASEMENT STROBE CCT #2		1030393	✓			✓			

ADDITIONAL: C2.6 ANNUNCIATOR AND REMOTE TROUBLE SIGNAL UNIT TEST AND INSPECTION

(Reference: Clauses 5.1.4, 5.4.1)

Annunciator or remote trouble signal unit location: Cell Area by Desk
 Annunciator or remote trouble signal unit identification: Ann 2

	YES	NO	N/A
A. Power 'ON' indicator operates.	✓		
B. Individual alarm and supervisory input zone clearly indicated and separately designated.	✓		
C. Individual alarm and supervisory input zone designation labels are properly identified.	✓		
D. Where active and supporting field devices are utilized, device labels shall be confirmed to correspond with actual field location.	✓		
E. Common trouble signal operates.	✓		
F. Visual indicator test (lamp test) operates.	✓		
G. Input wiring from control unit or transponder is supervised.	✓		
H. Alarm signal silence visual indicator operates.	✓		
I. Switches for ancillary functions operate as per design and specification, or in accordance with documentation as detailed in Appendix E, Description of Fire Alarm System for Inspection and Test Procedures.			✓
J. Other ancillary functions visual indicators operate.			✓
K. Manual activation of alarm signal and indication operates.	✓		
L. Displays are visible in installed location.	✓		
M. Operates on emergency power.	✓		
N. Multi-line sequential display operates as per Clause 6.4.1(N), where utilized.	✓		

ADDITIONAL: C2.7 ANNUNCIATORS OR SEQUENTIAL DISPLAYS

(Reference: Clauses 6.1.4, 6.4.2)

Annunciator or remote trouble signal unit location: Cell Area by Desk
 Annunciator or remote trouble signal unit identification: ANN 2

	YES	NO	N/A
A. Power on indicator operates	✓		
B. Individual alarm and supervisory zone indication operates.	✓		(see exception)
<i>Exception:</i> Operation of each individual alarm & supervisory zone indication gives the identical indication, or lights the identical indicators at the other annunciator(s), and sequential display(s). Specify method of confirmation: <u>VISUAL CONFIRMATION</u>	✓		
Minimum of one alarm zone and one supervisory zone tested per annunciator or sequential display to confirm operation.	✓		
C. Individual alarm and supervisory input zone designation labels are properly identified.	✓		
D. Where active and supporting field devices are utilized, device labels shall be confirmed to correspond with actual field location.	✓		
E. Common trouble signal operates.	✓		
F. Visual indicator test (lamp test) operates.	✓		
G. Input wiring from control unit or transponder is supervised.	✓		
H. Alarm signal silence visual indicator operates.	✓		
I. Switches for ancillary functions operate as per design and specification, or in accordance with documentation as detailed in Appendix E, Description of Fire Alarm System for Inspection and Test Procedures.			✓
J. Ancillary functions visual indicators operate.			✓
K. Manual activation of alarm signal and indication operates.	✓		
L. Displays are visible in installed location.	✓		

ADDITIONAL: C2.6 ANNUNCIATOR AND REMOTE TROUBLE SIGNAL UNIT TEST AND INSPECTION

(Reference: Clauses 5.1.4, 5.4.1)

Annunciator or remote trouble signal unit location: Front Entrance Desk Area Calling Centre
 Annunciator or remote trouble signal unit identification: ANN 3

	YES	NO	N/A
A. Power 'ON' indicator operates.	✓		
B. Individual alarm and supervisory input zone clearly indicated and separately designated.	✓		
C. Individual alarm and supervisory input zone designation labels are properly identified.	✓		
D. Where active and supporting field devices are utilized, device labels shall be confirmed to correspond with actual field location.	✓		
E. Common trouble signal operates.	✓		
F. Visual indicator test (lamp test) operates.	✓		
G. Input wiring from control unit or transponder is supervised.	✓		
H. Alarm signal silence visual indicator operates.	✓		
I. Switches for ancillary functions operate as per design and specification, or in accordance with documentation as detailed in Appendix E, Description of Fire Alarm System for Inspection and Test Procedures.			✓
J. Other ancillary functions visual indicators operate.			✓
K. Manual activation of alarm signal and indication operates.	✓		
L. Displays are visible in installed location.	✓		
M. Operates on emergency power.	✓		
N. Multi-line sequential display operates as per Clause 6.4.1(N), where utilized.	✓		

ADDITIONAL: C2.7 ANNUNCIATORS OR SEQUENTIAL DISPLAYS

(Reference: Clauses 6.1.4, 6.4.2)

Annunciator or remote trouble signal unit location: Front Entrance Desk Area Calling Centre
 Annunciator or remote trouble signal unit identification: ANN 3

	YES	NO	N/A
A. Power on indicator operates	✓		
B. Individual alarm and supervisory zone indication operates.	✓		(see exception)
<i>Exception:</i> Operation of each individual alarm & supervisory zone indication gives the identical indication, or lights the identical indicators at the other annunciator(s), and sequential display(s). Specify method of confirmation: <u>VISUAL CONFIRMATION</u>	✓		
Minimum of one alarm zone and one supervisory zone tested per annunciator or sequential display to confirm operation.	✓		
C. Individual alarm and supervisory input zone designation labels are properly identified.	✓		
D. Where active and supporting field devices are utilized, device labels shall be confirmed to correspond with actual field location.	✓		
E. Common trouble signal operates.	✓		
F. Visual indicator test (lamp test) operates.	✓		
G. Input wiring from control unit or transponder is supervised.	✓		
H. Alarm signal silence visual indicator operates.	✓		
I. Switches for ancillary functions operate as per design and specification, or in accordance with documentation as detailed in Appendix E, Description of Fire Alarm System for Inspection and Test Procedures.			✓
J. Ancillary functions visual indicators operate.			✓
K. Manual activation of alarm signal and indication operates.	✓		
L. Displays are visible in installed location.	✓		

