

### C3 FIELD DEVICE RECORD

(Reference: Clause 6.1 6)

#### C6.1 FIELD DEVICE TESTING - LEGEND & NOTES

(Reference: Clauses 6.7.4.1.3, 6.7.4.1.4, 6.7.4.1.5, 6.7.4.3.1, 6.7.4.5.1, 6.7.8.1.1, 6.7.8.2.2, 6.7.8.2.4)

DEVICE	DESCRIPTION	MANUFACTURER	MODEL NO.
M	Manual Station	EDWARDS	275C-C211
M2	Manual Station		
M3	Manual Station		
RHT	Rate of Rise Heat Detector		
RHT2	Rate of Rise Heat Detector		
RHT3	Rate of Rise Heat Detector		
HT	Fixed Temperature Heat Detector		283C
HT2	Fixed Temperature Heat Detector		
HT3	Fixed Temperature Heat Detector		
S	Smoke Detector	EST	EDW1400A
	Sensitivity Test Method:		
	Sensitivity Range:		
S2	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
S3	Smoke Detector		
	Sensitivity Test Method:		
	Sensitivity Range:		
RI	Remote Indicator		
DS	Duct Smoke Detector		
SFD	Supporting Field Device - Monitor		
SFD2	Supporting Field Device - Monitor		
FD	Sprinkler Flow Switch		
SS	Sprinkler Supervisory Device		
PS	Sprinkler Pressure Device		
IM	Isolation Module		
B	Bell	EDWARDS	439D-10AW
B2	Bell		
H/V	Horn/Visual		
H/V2	Horn/Visual		
H	Horn		
H2	Horn		
V	Visual Signal Device		
V2	Visual Signal Device		
SP	Cone Type Speaker		
SP2	Cone Type Speaker		
HSP	Horn Type Speaker		
AD	Ancillary Device		
AD2	Ancillary Device		
ET	Emergency Telephone		
EOL	End of Line Resistor/Capacitor		EOL-P1
EOL2	End of Line Resistor/Capacitor		

BUILDING NAME:	RCMP KILLARNEY DETACHMENT
BUILDING ADDRESS:	322 PARK ST. EAST KILLARNEY MB.
DATE:	MONDAY MARCH 22,2021

### C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
GENERAL OFFICE EAST / EAST WALL	FACP	EST1	✓		✓	✓	✓		R1,D3
ZONE 1:									
OFFICE AREA :									
ENTRANCE	M	Z1	✓		✓	✓	✓		
MAIN GENERAL OFFICE	HT	Z1	✓		✓	✓	✓		O1
INNER EXHIBIT ROOM	S	Z1	✓	x	✓	✓	✓		D1
OUTER EXHIBIT ROOM	S	Z1	✓	x	✓	✓	✓		D1
HALL TO CELL AREA	S	Z1	✓	x	✓	✓	✓		D1
MAIN FLOOR EAST OFFICE	HT	Z1	✓		✓	✓	✓		O1
OFFICE ELECTRICAL ROOM	S	Z1	✓	x	✓	✓	✓		D1
FILE/LUNCH ROOM	HT	Z1	✓		✓	✓	✓		O1
CORPORALS OFFICE	HT	Z1	✓		✓	✓	✓		O1
REAR EXIT	M	Z1	✓		✓	✓	✓		
BY REAR EXIT	EOL	Z1	✓		✓	✓			
SARGENTS OFFICE	HT	Z1	✓		✓	✓	✓		O1
2ND FLOOR :									
STAIRS	S	Z1	✓	x	✓	✓	✓		D1
BOARD ROOM	HT	Z1	✓		✓	✓	✓		O1
STORAGE AREA	HT	Z1	✓		✓	✓	✓		O1
BASEMENT :									
TOP OF STAIRS	S	Z1	✓	x	✓	✓	✓		D1
FURNACE ROOM	HT	Z1	✓		✓	✓	✓		O1
WASHROOM	HT	Z1	✓		✓	✓	✓		O1
MAIN ROOM	HT	Z1	✓		✓	✓	✓		O1
ZONE 2 CELL AREA :									
CELL AREA EXIT	M	Z2	✓		✓	✓	✓		
CELL 1 HALL	S	Z2	✓	x	✓	✓	✓		D1
CELL 2 HALL	S	Z2	✓	x	✓	✓	✓		D1
BOOKING AREA	S	Z2	✓	x	✓	✓	✓		D1,O2
CELL 2	S	Z2	✓	x	✓	✓	✓		D1,O2
CELL 1	S	Z2	✓	x	✓	✓	✓		D1,O2
BOOKING AREA	EOL	Z2	✓		✓	✓			
SOFT INTERVIEW ROOM	S	Z2	✓	x	✓	✓	✓		D1
BREATHALIZER ROOM	S	Z2	✓	x	✓	✓	✓		D1
SIGNALS :									
GENERAL OFFICE BY FACP	B	NAC2	✓		✓	✓			
GENERAL OFFICE BY FACP	EOL	NAC2	✓		✓	✓			
GENERAL OFFICE WEST	B	NAC1	✓		✓	✓			
GENERAL OFFICE WEST	EOL	NAC1	✓		✓	✓			

