



BUILDING NAME:	RCMP MINNEDOSA DETACHMENT
BUILDING ADDRESS:	276-1ST ST. S/W MINNEDOSA MB.
DATE:	THURSDAY FEB. 3,2022

### C3.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.7.1.3, C3.1)

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
FRONT ENTRANCE	FACP	MIRCOM FA-1000	✓		✓	✓	✓		
CELL AREA DESK	ANN	MIRCOM REMOTE ANN	✓		✓	✓	✓		
DEVICES :									
ZONE 5: MAIN FLOOR									
OFFICE AREA	EOL	Z5	✓		✓	✓			
INTERVIEW ROOM BY CELL HALL	S	Z5-4	✓		✓	✓	✓	2.6%	O1
OFFICE AREA 1	S	Z5-2	✓		✓	✓	✓	2.6%	
JANITORS ROOM	RHT	Z5-5	✓		✓	✓	✓		
OFFICE AREA 1 OFFICE	RHT	Z5-3	✓		✓	✓	✓		
MAIN ENTRANCE VESTIBULE	M	Z5-1	✓		✓	✓	✓		
OFFICE AREA 2	S	Z5-6	✓		✓	✓	✓	2.4%	
OFFICE AREA 2 OFFICE	S	Z5-7	✓		✓	✓	✓	2.4%	
ZONE 6: 2ND FLOOR									
HALL BY WASHROOM	EOL	Z6	✓		✓	✓			
HALL BY WASHROOM	M	Z6-1	✓		✓	✓	✓		
TOP OF STAIRS	S	Z6-2	✓		✓	✓	✓	2.4%	
BREAK ROOM	S	Z6-3	✓		✓	✓	✓	2.6%	
GYM	S	Z6-4	✓		✓	✓	✓	2.4%	
ZONE 7: BASEMENT									
TOP OF BASEMENT STAIRS	EOL	Z7	✓		✓	✓			
TOP OF BASEMENT STAIRS	M	Z7-6	✓		✓	✓	✓		
TOP OF BASEMENT STAIRS	S	Z7-5	✓		✓	✓	✓	2.6%	
OUTER EXHIBIT ROOM	S	Z7-3	✓		✓	✓	✓	2.6%	
INNER EXHIBIT ROOM	S	Z7-4	✓		✓	✓	✓	2.4%	
FURNACE ROOM	RHT	Z7-1	✓		✓	✓	✓		
STORAGE ROOM	RHT	Z7-2	✓		✓	✓	✓		
ZONE 8: BASEMENT DUCT SMOKES									
OFFICE AREA 1 FURNACE	DS	Z8-1	✓		✓	✓	✓		
OFFICE AREA 2 FURNACE	DS	Z8-2	✓		✓	✓	✓		
FURNACE ROOM	EOL	Z8	✓		✓	✓			
ZONE 9: CELL AREA DUCT SMOKE									
COLD STORAGE ROOM	DS	Z9-1	✓		✓	✓	✓		
OUTSIDE MECHANICAL ROOM	EOL	Z9	✓		✓	✓			
ZONE 1: CELL 1									
CELL 1	S	Z1-1	✓		✓	✓	✓	2.4%	O1
CELL HALL	EOL	Z1	✓		✓	✓			

Location	Device (See Legend)	Zone Circuit Number or Address	Correctly Installed	Requires Service	Alarm Operation Confirmed	Output Circuit Operation Confirmed	Annunciation Indication Confirmed	Reading / Measurement (Sensitivity, Pressure, Time Delay, etc)	Remarks / Required Additional Notes
ZONE 2: CELL 2									
CELL 2	S	Z2-1	✓		✓	✓	✓	2.6%	O1
CELL AREA	EOL	Z2	✓		✓	✓			
ZONE 3: CELL AREA									
CELL AREA	EOL	Z3	✓		✓	✓			
CELL AREA COPY ROOM	S	Z3-4	✓		✓	✓	✓	2.4%	
FRONT DESK	S	Z3-3	✓		✓	✓	✓	2.6%	
GUARD STATION WASHROOM	S	Z3-7	✓		✓	✓	✓	2.4%	
CELL HALL	S	Z3-2	✓		✓	✓	✓	2.6%	
BY EXIT	M	Z3-1	✓		✓	✓	✓		
OUTSIDE STORAGE	RHT	Z3-5	✓		✓	✓	✓		
OUTSIDE STORAGE	M	Z3-6	✓		✓	✓	✓		
CALL ROOM	S	Z3-8	✓		✓	✓	✓	2.4%	O1
ZONE 4: GARAGE									
EXIT	EOL	Z4	✓		✓	✓			
EXIT	M	Z4-2	✓		✓	✓	✓		
GARAGE	RHT	Z4-1	✓		✓	✓	✓		
SIGNALS : NAC1									
2ND FLOOR	HV	NAC1	✓		✓	✓			
OFFICE AREA 2	HV	NAC1	✓		✓	✓			
OFFICE AREA 1	HV	NAC1	✓		✓	✓			
CELL AREA	HV	NAC1	✓		✓	✓			
BASEMENT	HV	NAC1	✓		✓	✓			
BASEMENT	EOL	NAC1	✓		✓	✓			
RELAYS:									
FAN SHUT DOWN	AD		✓		✓	✓			

BUILDING NAME:	RCMP MINNEDOSA DETACHMENT	
BUILDING ADDRESS:	276-1ST ST. S/W MINNEDOSA MB.	
DATE:	THURSDAY FEB. 3,2022	
TEST NG PERFORMED BY:		

Printed Name

Signature

### EXIT AND EMERGENCY LIGHTING TEST AND INSPECTION RECORD

Legend: BP = Battery Pack, 1BP = BP w/ 1 Head, 2BP = BP w/ 2 Heads, CP = Combo Pack, RH1 = Single Remote Head, RH2 = Dual Remote Head, ES = Exit Sign

Location	Unit Type (See Legend)	Unit Primary Voltage (VAC)	Rated Unit Emergency Voltage (VDC)	Unit Size (Watts)	Requires Service (damaged, poor, or light battery condition)	Operation Confirmed	Heads properly aligned	Exit direction indicators correct	Duration of Test Time (minutes)	Test Time Result ✓ = Pass, ✗ = Fail	Remarks / Deficiencies / Corrective Action
GENERAL OFFICE	BP	12V		216W		✓			30	✓	EMERGI-LITE 12ESL216 1-12V 12AH BATTERY.
BY RECEPTION	ES					✓		✓		✓	
GENERAL OFFICE 1	RH2					✓	✓			✓	
HALL BY WOMENS WASHROOM	RH2					✓	✓			✓	
HALL BY MENS WASHROOM	ES					✓		✓		✓	
CELL AREA HALL	RH2					✓	✓			✓	
CELL AREA NORTH HALL	ES					✓		✓		✓	
CELL AREA EXIT	ES					✓		✓		✓	
CELL AREA BY DESK	RH1					✓	✓			✓	
GENERAL OFFICE 2	RH2					✓	✓			✓	
GENERAL OFFICE 2 BY STAIRS	ES					✓		✓		✓	
BASEMENT STAIRS	RH1					✓	✓			✓	
2ND FLOOR STAIRS	RH1					✓	✓			✓	
GARAGE	RH1					✓	✓			✓	
GARAGE	ES					✓		✓		✓	