



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services Canada

See herein for bid submission

instructions/

Voir la présente pour les

instructions sur la présentation

d'une soumission

Winnipeg

Manitoba

NA

Bid Fax: (418) 566-6167

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada
Northern Contaminated Site Program
Canada Place/Place du Canada
10th Floor/10e étage
9700 Jasper Ave/9700 ave Jasper
Edmonton
Alberta
T5J 4C3

Title - Sujet Coral Harbor Remediation Projet d'assainissement de Coral Harbour	
Solicitation No. - N° de l'invitation EW699-222278/B	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client CIRNAC EW699-222278	Date 2022-12-06
GETS Reference No. - N° de référence de SEAG PW-\$NCS-030-12338	
File No. - N° de dossier NCS-1-44134 (030)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Central Standard Time CST on - le 2022-12-20 Heure Normale du Centre HNC	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Calixto, Monnette	Buyer Id - Id de l'acheteur ncs030
Telephone No. - N° de téléphone (204) 899-9768 ()	FAX No. - N° de FAX (418) 566-6167
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Solicitation Amendment #003 is raised to modify Solicitation EW699-22278/B as follows:

1. Bidders Questions and Answers:

Q1. Please confirm if the LLDPE liner for the NHW facility is smooth, single sided textured or double-sided textured material?

A1. LLDPE liner does not require a textured surface. Smooth liner is acceptable.

Q2. Please confirm the colour of LLDPE liner required for the NHW facility?

A2. There are no specific colour requirements; however, the LLDPE must satisfy geomembranes specification 31 32 19.02 clauses 2.1.1.1 and 2.1.2 for UV resistance and carbon black content.

Q3. Can camp facilities older than 10 years be used if they are in an equivalent condition to newer units?

A3. Camp facilities older than 10 year can be used as long as they are in good condition and meet the requirements of the specifications.

Q4. The summary of work (Section 01 11 00 of the specs) indicate that we have to submit the site medic credentials but the health and safety section (01 35 29.13) of the specs indicate only First Aid attendants, not medic. Is a medic required full-time on site?

A4. A medic will not be required due to the proximity to the Coral Harbour nursing station. Contractors may choose to exceed the minimum requirements.
Remove:
Section 01 11 00 Clause 1.11.1.21 - In its entirety
Replace with
.12 Site Medic and/or First Aid Attendant credentials.

Q5. The specifications text in Sections 02.65.00.01 and 02 81 01 indicate that the liquids from the FSTS, vehicles, buried concrete structure and barrels that meet the incineration criteria are to be incinerated on site while Table A-5 indicate that those liquids are to be disposed off-site. Which one is the good one?

A5. Not all of the liquids estimated to be contained within the FSTS, vehicles, barrels, concrete structure, etc. has been sampled and classified. Assumptions were made based on the available sample results to estimate the portion of the contents that will not meet incineration criteria. Both the liquids referred to in the specifications and the liquids referred to in Table A5 will need to be disposed of. Liquid contents referred to in the specifications associated with payment items 02 81 01-1, 02 81 01-2, 02 81 01-3 and 02 81 01-4 are assumed to meet incineration criteria and may be disposed of through incineration on-site. The liquid contents referred to in Table A5 are assumed to not meet incineration criteria and will require off-site disposal.

Q6. In section 1.1 of Spec Section 01 71 00, is it a requirement that the registered surveyor has to be onsite or can the surveyor supervise the work remotely with regular visits to site from time to time?

A6. A registered surveyor will be required to complete the survey work as described in the specifications.

Q7. In section 1.8.3 of Spec Section 01 71 00, are the specifications for accuracy correct? Can the vertical accuracy (0.01 m) be relaxed similar to the horizontal limit of (0.1 m) specified?

A7. The accuracy tolerances will remain as described in the specifications as they are required to confirm the specified site tolerances during fill placement.

Q8. In section 1.8.5 of Spec Section 01 71 00, are all drawings submitted to be signed by a NAPEG-registered professional engineer or can these signed by the registered surveyor as specified in section 1.1 of Spec Section 01 71 00.

A8. PSPC will accept drawings, as described in Section 07 71 00, that have been signed by a qualified registered surveyor.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.