



NOTE TO CONTRACTOR
Accuracy in the location and elevation of columns and bearings shall be of essence of this structure.

NOTES

1. C.S.A. Specifications shall apply throughout.
2. Concrete: 3,000 psi, 28 days unless otherwise noted on drawings.
3. Reinforcing Steel: to be hard grade billet steel or half steel deformed bars throughout unless otherwise noted. (Yield point 50,000 Min.)
4. See General Specifications.
5. Pavement, Curb and Sidewalks are not in this contract.

NO.		REVISIONS		NAME		DATE	
DEPARTMENT OF PUBLIC WORKS CANADA DEVELOPMENT ENGINEERING BRANCH STRUCTURES DIVISION LEN'S SNOWSHED TCH MI-11.60 GLACIER NATIONAL PARK GENERAL LAYOUT							
JOB SUPERVISION	S. J. Stinner	DESIGN	J.C.D.	CHECK	T.D.		
APPROVED	DATE 2/1/81	DRAWN	I.R.P.	CHECK	T.D.		
PROJECT NO.		SD-104					
APPROVED		DATE 2/1/81					
SHEET		3		OF		18	

AA002268

CHIEF ENGINEER