

NOTES:

BUILT-UP ROOFING, INSULATION, FLASHINGS, CANTS, WOOD NAILERS, STEEL BEARING PLATES, CUTTING OR FRAMING OF ROOF OPENINGS, ETC., NOT INCLUDED IN THIS CONTRACT UNLESS NOTED.

ROOF DRAIN AND VENTILATOR OPENINGS, IF INCLUDED IN THIS CONTRACT, CUT BY ROSCO AT THE TIME OF ERECTION, LOCATED BY OTHERS.

ERECTION NOTE:

THE STEEL DECKING SHALL BE WELDED TO SUPPORTING STEEL BY MEANS OF 3/4" DIA. ARC WELDS AT 12" C. TO C. MAX. THESE WELDS SHALL BE FORMED AT ALL BEARING POINTS. BETWEEN SUPPORTING STEEL MEMBERS THE SIDE-LAPPING DECK RIBS SHALL BE TACK WELDED OR CLINCHED AT 36" C. TO C. MAX.

SHOWN HEREON IS OUR INTERPRETATION OF JOB DIMENSIONS AND REQUIREMENTS. SAME IS BASED ON DRAWINGS NUMBERED _____

DATED _____ BY _____

WHICH WE UNDERSTAND ARE FINAL AND OFFICIAL. THIS DRAWING IS SUBMITTED FOR YOUR APPROVAL.

SHOULD FUTURE DRAWINGS SUCCEED THOSE WHICH WE HAVE USED AS OUTLINED ABOVE AFTER FABRICATION OF OUR MATERIAL HAS BEGUN, IT IS THE RESPONSIBILITY OF THE PURCHASER TO REIMBURSE US FOR ANY WORK ALREADY PROCESSED OR IN PROCESS, AND FURTHER, TO PROVIDE US WITH AMENDED DRAWINGS AND OBTAIN A RECEIPT FROM US FOR SAME, AND IF NECESSARY, TO NEGOTIATE A NEW PRICE BASED ON REVISIONS.

FOR APPROVAL ONLY

DEPT. OF PUBLIC WORKS
CANADA
APPROVED AS NOTED | DATE June 21/1963
T. Haug ENGINEER-IN-CHARGE
FOR CHIEF ENGINEER

ROSCO METAL & ROOFING PRODUCTS LTD.

LEN'S SNOW SHED EXTENSION GLACIER NAT. PARK
INSPECTION PIPE & ACCESS DOOR
MILE 11.68

CUSTOMER

LEN'S CAL028250