



Vendor / Sous-traitant

0	DESCRIPTION	BY	yyyy-mm-dd
rev	description	by	date
Asset - Actif			
LOUIS S. ST-LAURENT			
Drawing - Dessin			
FIRE MAIN RENEWAL-SPRING 2022 BRIDGE DK			
designed - conception		date	
drawn - dessiné		date	
J. SEITZ		2022-10-06	
checked - vérifié		date	
approved - approuvé		date	
CCG ref. no. - no. réf. GCC		scale - échelle	
H-08		1:100	
drawing no. - no. dessin		sheet-feuille	rev
		04/05	0

File / Fichier: FIRE MAIN RENEWAL DRAWING.DWG - Printed / Imprimé: 2022/10/06 9:42

ANSI B

FIRE STATION 6

- 1- 2 1/2" ANGLE HOSE VALVE
W/ADAPTER
- 1- 1" WASHDECK VALVE
- 1- FABRICATED HOSE RACK
- 2" RUBBER LINED HOSE
WITH BRASS DIRECTOR

BRIDGE DECK

FIRE STATION 5

- 1- 2 1/2" ANGLE HOSE VALVE
W/ADAPTER
- 1- 1" WASHDECK VALVE
- 1- FABRICATED HOSE RACK
- 50 FT. Ø2" RUBBER LINED HOSE
WITH BRASS DIRECTOR

FIRE STATION 4

- 1- 2" STRAIGHT HOSE VALVE
- 1- FABRICATED HOSE RACK
- 1- 50 FT. Ø2" RUBBER LINED
HOSE WITH BRASS DIRECTOR

NOT ADDRESSED
IN THIS PERIOD

FORWARD ENGINE
ROOM CASING

UP TO FIRE
STATION 1

DOWN TO
FIRE MAIN

UP TO FIRE
STATION 3

2"

2 1/2"
2"

DN

UP

UP TO FIRE
STATION 2

UP

4

3

0 1
millimeters

2

3

5

6

7 8
millimètres

2

1