



RETURN BIDS TO:

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-855-983-1808

Bid E-mail Address: soumissionsami-bidsrpc@pc.gc.ca

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

REVISION 001 TO AN INVITATION TO TENDER

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Issuing Office:

Parks Canada Agency
National Contracting Services
Calgary, AB

Title: Snowshed Column Renovations, Mount Revelstoke and Glacier National Park	
Solicitation No.: 5P468-22-0222/A	Date: January 10, 2023
Amendment No.: 001	
Client Reference No.: 2290	
GETS Reference No.: PW-22-01017438	

Solicitation Closes: At: 2:00 PM On: January 17, 2023	Time Zone: MST
----------------------------------------------------------------------------------	--------------------------

F.O.B.: Plant: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other: <input type="checkbox"/>	
Address Enquiries to: Ken Lacanilao	
Telephone No.: (587) 832-1894	Fax No.: (855) 983-1808
Email Address: kenneth.lacanilao@pc.gc.ca	
Destination of Goods, Services, and Construction: See Herein	

TO BE COMPLETED BY THE BIDDER

Vendor/ Firm Name:	
Address:	
Telephone No.:	Email Address:
Name of person authorized to sign on behalf of the Vendor/ Firm (type or print):	
Signature:	Date:

Amendment 001

This amendment is raised to provide responses to bidder questions.

A. Questions and Answers

- Q1.** Please provide a Waterproofing material specification. Please provide a Preferred product list, if available.
- A1.** Waterproofing membrane shall be as per BC MoT Recognized Products List, Alberta Transportation Recognized Products List, or approved equivalent.
- Q2.** Please clarify how the snow fence timber will be attached and spaced to the steel-wide flange.
- A2.** The snow fence timbers are not mechanically attached to the steel flanges. Snow fence timbers sit in place with timber block spacers. Timber spacers are spiked to adjacent snow fence timber to secure (8" hot dip galvanized spikes).
- Q3.** We would like to request a one (1) week extension to the tender closing date.
- A3.** PCA will not be issuing an extension at this time.

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED.