



RETURN BIDS TO:

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-855-983-1808

Bid E-mail Address: soumissionsami-bidsrpc@pc.gc.ca

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

REVISION 003 TO AN INVITATION TO TENDER

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Issuing Office:

Parks Canada Agency
National Contracting Services
Calgary, AB

Title: Snowshed Column Renovations, Mount Revelstoke and Glacier National Park	
Solicitation No.: 5P468-22-0222/A	Date: January 16, 2023
Amendment No.: 003	
Client Reference No.: 2290	
GETS Reference No.: PW-22-01017438	

Solicitation Closes: At: 2:00 PM On: January 24, 2023	Time Zone: MST
--	--------------------------

F.O.B.: Plant: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other: <input type="checkbox"/>	
Address Enquiries to: Ken Lacanilao	
Telephone No.: (587) 832-1894	Fax No.: (855) 983-1808
Email Address: kenneth.lacanilao@pc.gc.ca	
Destination of Goods, Services, and Construction: See Herein	

TO BE COMPLETED BY THE BIDDER

Vendor/ Firm Name:	
Address:	
Telephone No.:	Email Address:
Name of person authorized to sign on behalf of the Vendor/ Firm (type or print):	
Signature:	Date:

Amendment 003

This amendment is raised to provide responses to bidder questions.

A. Questions and Answers

Q1. Please clarify Note 4 on Sheet 104:

- “Temporary supports to provide equal support to the roof beam on either side of the column under rehab.”
- “Temporary supports to provide a minimum factored vertical capacity of 1400kN.”
- “Jack temporary supports to reduce load in column being rehabilitated by 800kN prior to starting concrete removals.”

Along column line B of the LEN's snowshed, is the intent for each temporary support post on either side of the column to have a capacity of 700kN?

A1. Yes. Along column line B of the Len's snowshed, the intent is for each temporary support post on either side of the column to have a minimum vertical capacity of 700 kN

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED.