

Addendum Addenda

No./No 1

Project Description / Description de projet M32 Rooms 115 & 116 Office Renovation		
Project No./No de projet 6205	Departmental Representative / représentant ministériel Benoit Ranger	Date 18-Jan-2023
Solicitation No./N° de sollicitation 22-58118		
Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.		
Nota: Cet addenda fait partie intégrale des dossiers d'appel; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.		

Item No	Description
1	<p>Question (english): Are alternative manufacturers acceptable for the heat pump or are we only to go with Moovair regarding the above-mentioned project out for tender?</p> <p>Question (français): Les fabricants alternatifs sont-ils acceptables pour la pompe à chaleur ou devons-nous s'adresser uniquement à Moovair pour ce projet?</p> <p>Answer (english): Refer to specification 00 10 00, section 5.</p> <p>Réponse (français): Référer au devis 00 10 00, section 5.</p>
2	<p>Question (english): What is the anticipated start date and completion date for this job?</p> <p>Question (français): Quelles sont les dates de début et de fin de ce projet?</p> <p>Answer (english): Refer to specification 00 10 00, section 3.</p> <p>Réponse (français): Référer au devis 00 10 00, section 3.</p>
3	<p>See attached DSR for rooms 115, 116, and 117.</p> <p>Voir RSD ci-joint pour les chambres 115, 116 et 117.</p>
4	<p>See attached "Mandatory Site Visit Attendance" sheet.</p> <p>Voir ci-joint la feuille "Visite de chantier obligatoire".</p>



Building ID: M32		Notes:									Functional Space: G026	
Date: Feb 15/11											Location: 116/117 Workshop	
Project #: PR-08-043											Inspector (s): BM, JB, DJ	
Building Materials:				ACM Assessment:						Report Reference:		
Location:	Homo. Mat. #:	Material Description:	System:	ACM (Y/N):	Friable (Y/N):	ACM Type:	Quantity:	Condition (G,F,P):	Access (A,B,C):	Response / Comments:	Drawing #:	Photo #:
Floor	na	Vinyl Flooring	Floor	N	-	-	-	-	-	-	-	-
Walls	na	Concrete	Wall	N	-	-	-	-	-	-	-	-
Ceiling	9	Plaster	Ceiling	N	-	-	-	-	-	-	-	-
Above Ceiling	na	-	-	-	-	-	-	-	-	-	-	-
Below Ceiling	na	FG DI	HVAC	N	-	-	-	-	-	-	-	-
	na	FG PI	Cond.	N	-	-	-	-	-	-	-	-
	na	FG PI	MPS	N	-	-	-	-	-	-	-	-
Material Description: MJC: Mud Joint Compound FI: Fitting Insulation: PI: Pipe Insulation DI: Duct Insulation FG: Fibreglass FT: Floor Tile CT: Ceiling Tile			Criteria for Condition of an ACM: G: ACM is in GOOD condition; No damage F: ACM is in FAIR condition; Less than 2% damage P: ACM is in POOR condition; Greater than 2% damage				Criteria for Access to an area containing ACM: A: All building occupants may have access to this area. B: Restricted to building staff only. C: Areas of the building behind walls or ceiling system.					

Mandatory Site Visit Attendance / Visite de chantier obligatoire

Project Description / Description de projet M32 Rooms 115 & 116 Office Renovation			Closing Date / Date de fermeture February 2, 2023 2:00 PM	
Solicitation No./N° de sollicitation 22-58118		Project No./No de projet 6205		1st Showing / 1er visite January 17, 2023 9:00 AM
Departmental Representative / représentant Benoit Ranger		Signature <i>Benoit Ranger</i>	Alternate / Substituts January 24, 2023	Question January 26, 2023
			2nd Showing / 2ieme visite January 18, 2023 9:00 AM	

COMPANY/ENTREPRENEUR	NAME/NOM	SIGNATURE	PHONE/TELEPHONE	EMAIL/COURRIEL
DUPLEX	WARREN JORDAN	<i>[Signature]</i>	804 6570	WARREN.J.DUPLEX@GMAIL.COM
Raymond	PSYCHE ST-MOUL	<i>[Signature]</i>	819-639-2766	PSYMON@CLAUDE.RAYMOND.CA
10401544 CANADA inc	A. DURAND	<i>[Signature]</i>	819-208-3555	ADURAND@GROUPE PROFEX.COM
SERVANT ELECTRIC	C. CAUVARSAV	<i>[Signature]</i>	613-789-3535	DONALD@ELECTRIC.COM
RAYMOND Group	S. LÉVES	<i>[Signature]</i>	613 916 9524	Sleger@groupe-raymond.ca
Cannorbye Const	Alynn Rouse	<i>[Signature]</i>	613-229-8546	grlynn@canorbye.com
<hr/>				
Day 2				
OP/BAAVEL CONST	CARLOS CENO	<i>[Signature]</i>	513-749-1311	CARLOS@BPAVELCONST.CA
MB FORD	MARC SEBASTIEN	<i>[Signature]</i>	613-580-3446	MARCE@MBFORD.CA
ENER-TECH	Pierre Diotte	<i>[Signature]</i>	613 223 2172	pierre@enrtech-electrical.ca
Serge Zimolc Construction	Serge Zimolc	<i>[Signature]</i>	613-880-7874	Serge@zimolcconstruction.com
FRECON CONST	BRAD DOROSZKIEWICZ	<i>[Signature]</i>	819 328 2963	ESTIMATING@FRECON.CA
LAPLANTE BUILDERS	TOM KENNEL	<i>[Signature]</i>	613 223 6131	CAROLE@LAPLANTE@ON.AIBN.COM
BMI	AHMED SHAMMENT	<i>[Signature]</i>	613-745-1890	ahmed@bmi-ind.com
PREMIUM Construction	RAFIK OUDSIDA	<i>[Signature]</i>	343-553-0725	RAFIK@PREMIUM-CONSTRUCTION.COM
Arrow Property Service	Grant Twilley	<i>[Signature]</i>	613-489-3652	gtwilley@arrow-service.ca

