

Parks Canada  
3 Passage du Chien-d'Or  
Québec QC G1R 3Z8  
(418) 928-7252

**Request for Information****Tender RFI Response 01**

**Project Name:** Reconstruct House on Lot 6 Block 5 in Resolute Bay  
**Project number:** Parks Canada 5P468-22-0209  
GA 20103  
**Date:** February 9, 2023  
**Attn:** Thuc Nguyen  
Asset Manager, Parks Canada

---

**1.0 Request:****1. Siding/Roof Steam Seam Panel page A803**

- The siding type 1 /roofing Vicwest galvalume is generally use for roofing. Do we still use him as siding type 1?

**2. Finish Schedule A802**


- In the washroom 106 and 203, it says the floor will be in VP2 but there's no vinyl plank 2 in the floor finish on page A803. It's also identified as VP1 in the details 1-2/A803. Can you confirm which one it is?

**1.0 Comments:**

1. Yes, the galvalume finish is to be used for the type 1 siding finish as noted on A803.
2. The VP2 on A802 can be disregarded. Washroom 106 and Washroom 203 are to receive a VP1 floor finish.

**End of Tender RFI Response 01**

Signed,



Lucas Meyer  
Project Manager, Guy Architects Ltd.