

RETURN BIDS TO:

Parks Canada Agency Bid Receiving Unit National Contracting Services

Bid Fax: 1-855-983-1808 Bid E-mail Address:

soumissionsami-bidsrpc@pc.gc.ca

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

REVISION 005 TO AN INVITATION TO TENDER

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Issuing Office:

Parks Canada Agency National Contracting Services Québec, G1R 3Z8

Title: Garage Construction in Resolute Bay, Nunavut			
Solicitation No.: 5P468-22-0210/A	Date: March 1, 2023		
Amendment No.: 005			
Client Reference No.: N/A			
GETS Reference No.: PW-23-01022140			
Solicitation Closes: At: 2:00 PM On: March 2, 2023	Time Zone: EST-HNE		

F.O.B.: Plant: □	Destination: ⊠	Other: □	
Address E Cloë Pellan	nquiries to: ad Tessier		
Telephone 418 928-72		Fax No.: 855 983-1808	
Email Address: cloe.pelland-tessier@pc.gc.ca			
Destination of Goods, Services, and Construction: Resolute Bay, Nunavut			

TO BE COMPLETED BY THE BIDDER

Vendor/ Firm Name:			
Address:			
Telephone No.:	Email Address:		
Name of person authorized to sign Firm (type or print):	on behalf of the Vendor/		
Signature:	Date:		



Solicitation No.: Amendment No.: Contracting Authority: 5P468-22-0210/A 005 Cloë Pelland Tessier

Client Reference No.: Title

N/A Garage Construction in Resolute Bay, Nunavut

Amendment 005

This amendment is raised to:

- A. Answer question from bidders;
- B. Make changes to the tender documents

A. Answer question from bidders

- **Q1.** In reference to the wall composition W1 received with amendment no. 002, the description does not match the wall section details of the drawings, example plan A404. On the section, an OSB on each side is added as well as a 25mm rigid insulating panel and a "furring channel". Which one should we follow? **A1.** As noted in Addendum #2, "W1 wall assembly noted on A102 to be revised as follows and to supersede all exterior wall assemblies shown in all details".
- **Q2.** In reference to detail 2, 3 and 4 on A401, a "tyvek wrb" is requested around the openings, usually this is a self-adhesive membrane, is this a mistake?
- A2. Yes. Tyvek wrb can be omitted.
- **Q3.** In reference to detail 4 on A404, a "38mm fire blocking" is requested for the continuity of the firewall separation, can you specify the product?
- A3. Acceptable materials are indicated in NBC 9.10.16.3.
- **Q4**. In reference to amendment no. 002, you provide models of shelving to be supplied, on the plans the exact location and quantity is not listed, is it possible to detail your needs?
- **A4**. It is the Contractor's responsibility to identify quantities to provide as much shelving as possible in the area indicated on A102.

B. Tender Package/ Solicitation Revisions

In: Final_specification documents_2022_4_14 and 21109_Resolute garage_IFT

Add this document that modify the Specifications and Drawings:

Addendum 5_TenderRFIResponse02_2023-02-28

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED.