

Parks Canada  
3 Passage du Chien-d'Or  
Québec, QC G1R 3Z8  
(418) 928-7252

**Request for Information****Tender RFI Response 02**

**Project Name:** Garage Construction in Resolute Bay, Nunavut  
**Project number:** Parks Canada 5P468-22-0210/A  
GA 21109  
**Date:** February 28, 2023  
**Attn:** Thuc Nguyen  
Asset Manager, Parks Canada

---

**2.0 Request:**

1. In reference to the wall composition W1 received with amendment no. 002, the description does not match the wall section details of the drawings, example plan A404. On the section, an OSB on each side is added as well as a 25mm rigid insulating panel and a "furring channel". Which one should we follow?
2. In reference to detail 2, 3 and 4 on A401, a "tyvek wrb" is requested around the openings, usually this is a self-adhesive membrane, is this a mistake?
3. In reference to detail 4 on A404, a "38mm fire blocking" is requested for the continuity of the firewall separation, can you specify the product?
4. In reference to amendment no. 002, you provide models of shelving to be supplied, on the plans the exact location and quantity is not listed, is it possible to detail your needs?

**2.0 Response:**

1. As noted in Addendum #2, "W1 wall assembly noted on A102 to be revised as follows and to supersede all exterior wall assemblies shown in all details".
2. Yes. Tyvek wrb can be omitted.
3. Acceptable materials are indicated in NBC 9.10.16.3.
4. It is the Contractor's responsibility to identify quantities to provide as much shelving as possible in the area indicated on A102.

**End of Tender RFI Response 02**

Signed,

  
Lucas Meyer  
Project Manager, Guy Architects Ltd.