

Parks Canada
3 Passage du Chien-d'Or
Québec QC G1R 3Z8
(418) 928-7252

Request for Information

Tender RFI Response 03

Project Name: Reconstruct House on Lot 6 Block 5 in Resolute Bay
Project number: Parks Canada 5P468-22-0209
GA 20103
Date: February 28, 2023
Attn: Thuc Nguyen
Asset Manager, Parks Canada

3.0 Request:

1. **Finish Schedule A802**


- The standard dimensions and thickness for the Altro Lavencia LVT are 6'' (152.4mm) x 48'' (1219.2mm) x 3mm. It's possible to have custom dimensions with a large minimal quantity but 6 mm thickness isn't possible for this model. Can you confirm the standard model is okay?

3.0 Response:

1. Please proceed with the standard 152x1219x3 mm tile size.

End of Tender RFI Response 03

Signed,



Lucas Meyer
Project Manager, Guy Architects Ltd.