



RETURN BIDS TO:

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-855-983-1808

Bid E-mail Address:

soumissionsami-bidsrpc@pc.gc.ca

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**REVISION 006 TO AN
INVITATION TO TENDER**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Issuing Office:

Parks Canada Agency
National Contracting Services
Québec, G1R 3Z8

Title: Reconstruct House on Lot 6 Block 5 in Resolute Bay, Nunavut	
Solicitation No.: 5P468-22-0209/A	Date: March 1, 2023
Amendment No.: 006	
Client Reference No.: N/A	
GETS Reference No.: PW-23-01022130	

Solicitation Closes: At: 2:00 PM On: March 2, 2023	Time Zone: EST-HNE
---	------------------------------

F.O.B.: Plant: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other: <input type="checkbox"/>	
Address Enquiries to: Cloë Pelland Tessier	
Telephone No.: 418 928-7252	Fax No.: 855 983-1808
Email Address: cloe.pelland-tessier@pc.gc.ca	
Destination of Goods, Services, and Construction: Resolute Bay, Nunavut	

TO BE COMPLETED BY THE BIDDER

Vendor/ Firm Name:	
Address:	
Telephone No.:	Email Address:
Name of person authorized to sign on behalf of the Vendor/ Firm (type or print):	
Signature:	Date:

Solicitation No.:
5P468-22-0209/A

Amendment No.:
006

Contracting Authority:
Cloë Pelland Tessier

Client Reference No.:
N/A

Title:
Reconstruct House on Lot 6 Block 5 in Resolute Bay, Nunavut

Amendment 006

This amendment is raised to answer questions from bidders and make changes to the tender documents

A. Questions and Answers

Q1. Finish Schedule A802

The standard dimensions and thickness for the Altro Lavencia LVT are 6" (152.4mm) x 48" (1219.2mm) x 3mm. It's possible to have custom dimensions with a large minimal quantity but 6 mm thickness isn't possible for this model. Can you confirm the standard model is okay?

A1. Please proceed with the standard 152x1219x3 mm tile size.

B. Tender Package/ Solicitation Revisions

In: ***20103_IFT_Specifications_Rev1_2022-11-18 and 20103_IFT_Rev1_2022-11-18***

Add this document that modifies the Specifications and Drawings:

- 20103_Addendum06_2023-02-28

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED.