



**AMENDMENT 02 to the RFQ 24-242269**

Supply and installation of pedestrian access control barriers (turnstiles) in one NCR location for the Global Affairs  
Canada

Amendment N° 2 is being issued in order to answer the questions #02 to #06 from the table below. These questions were asked and answered during the site visit at 200 Promenade du Portage, Gatineau (QC) at 1:00 pm.

<b>Q#</b>	<b>Question</b>	<b>Answer</b>
<b>02</b>	Why are the PACB's being changed?	End of Life; Can no longer obtain parts to repair as the manufacturer went out of business.
<b>03</b>	How many need to be accessible?	All refer to Annex A - SOW requirements contained in the bid solicitation document.
<b>04</b>	Where is the electrical run?	The electrical and Access control wires are run on top of the floor covered by the PACB's , floor bridge covers and glass wall structure up to an electric panel on the wall of the reception area, console side.
<b>05</b>	Who services the PACB's currently?	- Ottawa Security (mechanical); - Honeywell (IDACs only)



<b>06</b>	Is it required to have card readers in and out.	<p>Yes – Maisonneuve readers entry and exit active 24/7 – 365.</p> <p>Yes – Main lobby readers entry and exit, entry active 24/7 – 365, exit active only during silent hours.</p> <p>Both sets have existing switches to open/close PACB's controlled by Commissionaires.</p> <p>Existing switches can be reused.</p>
-----------	---	---

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED