



RETURN BIDS TO:

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-855-983-1808

Bid E-mail Address: soumissionsami-bidsrpc@pc.gc.ca

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**REVISION 003 TO
REQUEST FOR PROPOSAL**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Issuing Office:

Parks Canada Agency
National Contracting Services
Calgary, AB

Title: Fort Chipewyan Staff Housing – Wood Buffalo National Park	
Solicitation No.: 5P468-23-0271/A	Date: February 19, 2024
Amendment No.: 003	
Client Reference No.: 2269	

Solicitation Closes: At: 2:00 PM On: March 07, 2024	Time Zone: MST
--	--------------------------

F.O.B.: Plant: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other: <input type="checkbox"/>	
Address Enquiries to: Ken Lacanilao	
Telephone No.: (587) 832-1894	Fax No.: (855) 983-1808
Email Address: kenneth.lacanilao@pc.gc.ca	
Destination of Goods, Services, and Construction: See Herein	

TO BE COMPLETED BY THE BIDDER

Vendor/ Firm Name:	
Address:	
Telephone No.:	Email Address:
Name of person authorized to sign on behalf of the Vendor/ Firm (type or print):	
Signature:	Date:

Amendment 003

This amendment is raised to:

- a. Answer questions from bidders

A. Questions and Answers

- Q6.** As the Net Zero requirements are generic at this point, we've received a range of quotes for the Net Zero energy modeling. How will the requirements be enforced?
- A6.** The energy targets for Thermal Energy Demand Intensity (TEDI) and Airtightness are required. The design will be modeled to ensure that it meets the TEDI requirement. For reference the TEDI target of 60 kWh/(m2 year) is roughly equivalent to Step 5 for the BC Energy Step Code for this climate and is a target we have used for several similar projects in the north. The airtightness target of less than one Air Changes per Hour at 50 Pa Pressure Differential is used in the modelling to predict the energy requirement of the future build. Because air leakage is such a significant driver of energy usage it will be tested during construction and after to confirm the building meets the target.
- Q7.** Will a labeling program be used (this tends to have its own energy and documentation requirements)?
- A7.** No, third party certification or labeling program is not required for this project.

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED.