

# NATIONAL BATTLEFIELDS COMMISSION

## Call for tenders – Access path to the Plains of Abraham Museum

March 19, 2024

### ADDENDUM NO 1

1. We have received the following questions. Please note that the questions and answers are an integral part of the addendum.

- a) In the architectural specifications, section 01 00 00, article 2.2 site visit, see the client's document. Where can I find this document?

Answers: No visits are planned, as this is a public place open to tenderers wishing to see the site.

- b) Is there a summary environmental characterization of the soils? If not, how will you manage soil disposal?

Answers: Several works have been carried out on the site where the work will take place, and several soundings have been made, none of which revealed the presence of soil contamination. No contamination is expected. Plan soil disposal in accordance with current regulations.

Contaminated soils: This amount is an allowance to compensate for costs incurred in disposing of B-C and C+ contaminated soils at an authorized site. It is payable by the tonne on presentation of the invoice accompanied by weighing tickets, plus 15% for transport costs. Should there be no contaminated soil to dispose of, no amount or compensation will be paid to the successful tenderer for this allowance.

The tender schedule has been revised to include an allowance in the event of soil contamination. It is included in the addendum (see attached).

- c) Is it possible to specify the color and format of all the paving types shown on the plans? At present, only one color has been specified and three types of paving (quote 32 14 13). The plan appears to show several different colors and types of paving.

Answers: The colors shown on the plans are only intended to make it easier to differentiate the paving finishes. In fact, there is only one color, which comes in two different finishes and three different sizes. Here's a table summarizing the nomenclature used in the plans/quotes to identify paving types. The paving number refers to the left-hand column (#), while the associated letter refers to the right-hand column (X):

#	Color and finish	X	Dimensions
1	Light beige, shot-blasted finish	A	600 x 100 mm, 100 mm thick
2	Light beige, smooth finish	B	450 x 100 mm, 100 mm thick
		C	150 x 150 mm, 100 mm thick

- d) Will any archaeological work be required for this project?

Answers: Refer to the instructions to tenderers in point 8, in the event that this work is necessary, the NBC will be mandated to select and supervise the work of the archaeologist.

2. **VERY IMPORTANT: A copy of your addendum must be included in your bid as proof that you have read the addendum. Otherwise, your tender will be rejected as non-compliant.**

Philippe Lafrenière  
National Battlefields Commission  
Supply, Material Resources and IT Assistant  
835, Wilfrid-Laurier Avenue, Québec (Québec) G1R 2L3  
Phone: (418) 948-2260