



RETURN OFFERS TO :
RETOURNER LES OFFRES À :
Bid Receiving - Réception des soumissions:

bidsubmissions.gen-nhqcontracting@csc-scc.gc.ca

**AMENDMENT TO THE REQUEST FOR
STANDING OFFER
MODIFICATION DE LA DEMANDE
D'OFFRE À COMMANDES**

National Master Standing Offer (NMSO)
Offre à commandes maître nationale (OCMN)

Proposal to: Correctional Service Canada

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

**Proposition à: Service Correctionnel du
Canada**

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Issuing Office – Bureau de distribution

Correctional Service Canada (CSC)

340 Laurier Avenue West
Ottawa ON
K1P 5K3

Title — Sujet: Drinking Water & Wastewater Laboratory Services	
Solicitation No. — N°. de l'invitation 21120-24-4672190	
Solicitation Amendment No. – No. de la modification à l'invitation 001	Date: April 5, 2024
GETS Reference No. — N°. de Référence de SEAG 21120-24-4672190	
Solicitation Closes — L'invitation prend fin at /à : 2PM On / Le : April 26, 2024	Time Zone Fuseau horaire Eastern Standard Time (EST)
Delivery Required — Livraison exigée : See herein – Voir aux présentes	
F.O.B. — F.A.B. Plant – Usine: Destination: Other-Autre:	
Address Enquiries to — Soumettre toutes questions à: Stephanie.gigoux@csc-scc.gc.ca	
Telephone No. – N° de téléphone:	Fax No. – N° de télécopieur:
Destination of Goods, Services and Construction: Destination des biens, services et construction: Multiple as per call-up Multiples, selon la commande subséquente.	
Instructions: See Herein Instructions : Voir aux présentes	



Request for Standing Offer (RFSO) Amendment 001 is issued to:

1. Respond to questions 1 through 1 received the during the solicitation period.

1. Questions and Answers 1 through 1:

Question 1: Can you confirm the detection limit you need for Mercury?

Answer 1: An MDL of 0.0001 mg/L (0.1 ug/L) or less is acceptable for mercury.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.



La modification 001 à la demande d'offres à commandes (DOC) est émise pour:

2. Répondre aux questions 1 à 1 reçues au cours de la période d'invitation.

2. Questions et réponses 1 à 1:

Question 1: Pouvez-vous confirmer la limite de détection dont vous avez besoin pour Mercure?

Réponse 1: Une LMD de 0.0001 mg/L (0.1 ug/L) ou moins est acceptable pour le mercure.

TOUTES LES AUTRES MODALITÉS RESTENT LES MÊMES.