



NORTHWEST TERRITORIES
POWER
CORPORATION

RFP/Q #: RFQ NO. 208125

RFP NAME: 22 MVA TRANSFORMER SUPPLY

TALTSON HYDRO, NORTHWEST TERRITORIES

1 **Question:** Regarding page 8 of Appendix D E and F, it states that transformers should be designed for parallel operation. Can you please confirm whether this implies that the two new transformers should be designed to operate in parallel, or if they should be designed to operate in parallel with any existing transformers?

Answer: The intent is for the two new transformers to operate in parallel and both be able to handle 22MVA individually if required, in the case of a failure.