



AMENDMENT 01 to the RFQ 24-248537
Supply and delivery of Air Purifiers and Air Filters for the Canadian Embassy in Jakarta

Amendment N° 1 is being issued in order to answer the following questions:

QUESTION #1:

To confirm, is bid 24-248535 **only for filters** and not actual air purifier units?

ANSWER #1:

Yes, correct

QUESTION #2:

We are interested in quoting on subject solicitation, pl. provide requirement quantity and voltage required, as understand Indonesia uses 220-240v and 50hz.

ANSWER #2:

Yes, Indonesia uses 230V so the air purifiers must be able to function using that voltage. The quantities are clearly indicated in the RFSO.

The SOW and Evaluation Criteria of the RFSO will be amended to reflect the 230V functionality. The RFSO version 02 will be posted and version 02 will supersede the original version.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED